

DEVELOPMENT FACILITATIVE TEAM (DFT) - **HYDROLOGY SECTION**

Richard Martinez, PE, Senior Engineer | 505-924-3362 richardmartinez@cabq.gov

DRB Project Number: 2024-011232 Hearing Date: 12-11-2024

Project: Lots 1&2, Block 49
Snow Heights Addition
9720 Candelaria Rd. NE
Between Eubank & Carol Agenda Item No: 7

<input checked="" type="checkbox"/> Sketch Plat	<input type="checkbox"/> Site Plan for Bldg. Permit
---	---

ENGINEERING COMMENTS:

- Hydrology has no objection to the sketch plat action, vacation of public utility easements.
- Prior to submitting for a Building Permit for any site upgrades, a licensed New Mexico civil engineer will need to submit a Grading & Drainage Plan to Hydrology for review & approval if one of these conditions is met. (500 cy of grading, 1,000 sf of proposed building, or 10,000 sf of proposed paving).

APPROVED
 DENIED

DELEGATED TO: TRANS HYD WUA PRKS PLNG
Delegated For: _____
SIGNED: I.L. SPSP SPBP FINAL PLAT
DEFERRED TO _____