

CITY OF ALBUQUERQUE



May 15, 2017

David Aube, P.E.
The Design Group
120 Vassar Dr NE, Suite 100
Albuquerque, NM

**Re: APS Family School NW-Work Order
Erosion and Sediment Control Plan
Engineer's Stamp Date 5-8-17 (A09E099)**

Dear Mr. Aube,

Based upon the information provided in your submittal received 5-9-17, the above referenced plan is approved to be included in the SWPP and the Work Order construction plans.

In general, Stormwater Quality does not approve the use of hay/straw bales as they fall apart and become debris. However, in this case, the site has a large dirt/vegetation area downhill from it so it will be a good case to evaluate the use of hay/straw bales.

PO Box 1293

Include a copy of the approved plan in the Work Order construction plans.

Albuquerque

If you have any questions, you can contact me at 924-3420.

New Mexico 87103

www.cabq.gov

Sincerely,

Curtis Cherne, P.E.
Principal Engineer, Stormwater Quality
Planning Dept.

C: email