

CITY OF ALBUQUERQUE

PLANNING DEPARTMENT – Development Review Services



January 20, 2015

Diane Hoelzer, P.E.
Mark Goodwin & Associates, P.A.
P.O. Box 90606
Albuquerque, NM 87199

Richard J. Berry, Mayor

**RE: Anasazi Ridge, Unit 3
Drainage Report, and Grading and Drainage Plan
Engineer's Stamp Date 1-12-2015 (File: A10D002G)**

Dear Ms. Hoelzer:

Based upon the information provided in your submittal received 1-13-15, the above referenced plan cannot be approved for Preliminary Plat and Site Plan for Subdivision until the following comments are addressed:

- a. Concrete spillway at Calle Vizcaya should be a rundown as opposed to a vertical drop.


PO Box 1293

If you have any questions, you can contact me at 924-3695.

Albuquerque

New Mexico 87103

www.cabq.gov

Sincerely,

Rita Harmon, P.E.
Senior Engineer, Planning Dept.
Development Review Services

Orig: Drainage file
c.pdf Addressee via Email