


# CITY OF ALBUQUERQUE



June 6, 2005

Jeffrey T. Wooten, P.E.  
Bohannon Huston, Inc.  
7500 Jefferson NE – Courtyard 1  
Albuquerque, NM 87109

**Re: Paradise Skies Park, Lot A1, Paradise Skies, Unit 5, Drainage and Grading Plan - Engineer's Stamp dated 5-17-05 (A11-D3A4)**

Dear Mr. Wooten,

Based upon the information provided in your submittal dated 5-17-05, the above referenced plan is approved for Building Permit and Work Order provided a manhole is used for the connection to the existing storm drain.

This project requires a National Pollutant Discharge Elimination System (NPDES) permit. Refer to the attachment that is provided with this letter for details. If you have any questions please feel free to call the Municipal Development Department Hydrology section at 768-3654 (Charles Caruso).

Please attach a copy of this approved plan to the construction sets prior to sign-off by Hydrology and prior to release of the Certificate of Occupancy an Engineer's Certification of the grading plan (including the above mentioned revision) per the DPM checklist will be required.

If you have any questions, you can contact me at 924-3990.

Sincerely,

Phillip J. Lovato, E.I.  
Associate Engineer, Planning Department  
Development and Building Services

C: Charles Caruso, DMD  
file

P.O. Box 1293

Albuquerque

New Mexico 87103

[www.cabq.gov](http://www.cabq.gov)