

CITY OF ALBUQUERQUE



March 28, 2014

G. Robert Adams, P.E.
Adams Engineering
910 South Kimball Avenue
Southlake, Texas 76092

Re: McDonalds – McMahon Marketplace - 5700 McMahon Blvd. NW
Erosion Sediment Control (ESC) Plan
Engineer's Stamp Date 3/20/2014 Sheet C3.0
Engineer's Stamp Date 2/21/2014 Sheet C3.1 (A11/E011B)

Dear Mr. Adams,


Based upon your submittal received 3-24-14, the above referenced Erosion Sediment Control (ESC) plan is acceptable for Building Permit based on the following condition:

_ NPDES Posting Board should be visible from public sidewalk or street.

This project requires a National Pollutant Discharge Elimination System (NPDES) permit for storm water discharge for disturbing one acre or more and a Topsoil Disturbance Permit for disturbing $\frac{3}{4}$ of an acre or more.

If you have any questions, you can contact me at 924-3422.

Sincerely,


Shahab Biazar, P.E.
Principal Engineer, Planning Dept.
Development Review Services

C: e-mail