

CITY OF ALBUQUERQUE



March 9, 2017

David Soule, P.E.
Inspections Plus Inc.
4382 Alexander Blvd NE
Albuquerque, NM 87107

**Re: Guardian Storage- Work Order
Erosion and Sediment Control Plan
Engineer's Stamp Date 3-8-17 (A11E015)**

Dear Mr. Soule,

Based upon the information provided in your submittal received 3-9-17, the above referenced plan is approved to be included in the SWPPP and to be included in the Work Order construction plans with the comment that:

1. Concerning the BMP "Saw Cut and/or Mulch Sock", it is not obvious that a saw cut will work in a street due to the amount of flow and the slope of the street.

Include a copy of the approved plan in the Work Order construction plans.

If you have any questions, you can contact me at 924-3420.

Sincerely,

Curtis Cherne, P.E.
Principal Engineer, Stormwater Quality
Planning Dept.

C: email