

# CITY OF ALBUQUERQUE



June 20, 2017

Mark Goodwin, P.E.  
Mark Goodwin and Associates  
P.O. Box 90606  
Albuquerque, NM 87199

**Re: McMahon Property Temporary Mass Grading  
Erosion and Sediment Control Plan  
Engineer's Stamp Date 6-16-17 (A11E016)**

Dear Mr. Goodwin,

Based upon the information provided in your submittal received 6-16-17, the above referenced plan is approved to be included in the SWPPP and to apply for an ESC Permit for grading, with the following condition:

1. The silt fence poles are to be spaced a maximum of 10 feet apart on the straight runs with closer pole spacing (depends on radius) around the corners on the downhill side.

PO Box 1293

Please revise detail for future submittals.

Albuquerque

Please pass on to the owner that depending on how long this site remains graded dirt (no permanent improvements) and if vegetation doesn't grow they may be asked to stabilize (Hydromulch or similar) it at a later date.

New Mexico 87103

If you have any questions, you can contact me at 924-3420.

[www.cabq.gov](http://www.cabq.gov)

Sincerely,

Curtis Cherne, P.E.  
Principal Engineer, Stormwater Quality  
Planning Dept.