



City of Albuquerque Stormwater Construction Site Inspection Report

General Information

ESC File No.	A11E017C	Project Name:	Tidal Wave Care Wash		
NPDES Id. No.	NIMR1005J2	Location:	10601 Unser Blvd		
5/8/2023	Owner	Contractor			
Operator	TWAS Properties LLC		Scarsgard Construction		
Contact name & title	Ryan Crumley		Jason Skarsgard		
e-mail	ryan.crumley@twavelead.com		jason@skarsco.com		
Contact Phone #	706-647-0414		262-2323		
COA Inspector	Doug Hughes		Start/End Time:	10:30AM	
Construction Phase:	Graded Lot 2 no construction active, lot is disturbed				
Type of Inspection:	<input type="checkbox"/> Regular	<input type="checkbox"/> Storm Event	<input type="checkbox"/> Post Storm Event >0.25"	<input type="checkbox"/> 311/Complaint	<input checked="" type="checkbox"/> Follow Up
Weather at time of inspection?	Clear		Temperature: ~	60	
Estimated date of last storm 0.25" or greater	3/16/2023				
Item Number	Deficiency/ Corrective Action				
1	Posting sign is laying on the ground and must be replaced				
2	Silt Fence is down in the North east corner and must be reset. It is full of sediment and needs maintained in several other places.				
3					
4					
5					
2.1	Discharge off site? (Y/N)	no			
4	Self Inspection Reports	n/a	Latest report Date:	5/4/2023	

Notes:

Tried to call Mr Crumley and operator said he doesn't have an extension and can only be reached by email. SWPPP isn't available onsite so not checked, and City is on distribution list for self inspection reports.

City of Albuquerque Stormwater Inspector Signature and date:

Contact information: Doug Hughes (505) 924-3420

jhughes@cabq.gov