

FILE COPY



City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

September 17, 1990

Jeff Mortensen, P.E.
Jeff Mortensen & Associates, Inc.
6010-B Midway Park Boulevard, NE
Albuquerque, New Mexico 87109

RE: ENGINEER'S CERTIFICATION FOR CIBOLA HIGH SCHOOL
SCIENCE BUILDING ADDITION (A-13/D4) RECEIVED SEPTEMBER 11, 1990

Dear Mr. Mortensen:

In response to your submittal, we are unable to review the certification for the science building addition until the pond is approved, completed and certified.

The pond is an integral portion for the runoff from the science building addition. Therefore, the system must be in place prior to release of any type of approval.

If I can be of further assistance, please feel free to call me at 768-2650.

Cordially,

for Benito Montoya
Fred J. Aguirre, P.E.
Hydrologist

xc: Myron Johnson, APS

BJM:FJA/bsj
(WP+1322)

PUBLIC WORKS DEPARTMENT

Walter H. Nickerson, Jr., P.E.
Assistant Director Public Works

ENGINEERING GROUP

Telephone (505) 768-2500

AN EQUAL OPPORTUNITY EMPLOYER