

CITY OF ALBUQUERQUE  
PLANNING DEPARTMENT  
DEVELOPMENT SERVICE / HYDROLOGY SECTION

DATE: 8-14-13  
CONFERENCE RECAP

ZONE ATLAS PAGE NO: A14  
DRAINAGE FILE: A14D001  
ZONING: \_\_\_\_\_  
DRB: \_\_\_\_\_  
SUBJECT: AA and Flooding in Corrales Rd  
STREET ADDRESS (IF KNOWN): \_\_\_\_\_  
SUBDIVISION NAME: \_\_\_\_\_

APPROVAL REQUESTED:

ATTENDANCE: Mike Walla Curtis Chene

FINDINGS:

1. Engineer to modify/improve stormwater entering small pond in AA location at hard corner of S28 and Corrales Rd.
2. Obtain survey data of grades across Service Rd (and pond) between bldg and offsite pond along Corrales Rd.
3. <sup>Hydrology</sup> ~~Engineer~~ to approve AA prior to submission of grading plan and ensure work is performed prior to CO.

THE UNDERSIGNED AGREES THAT THE ABOVE FINDINGS ARE SUMMARIZED ACCURATELY AND ARE SUBJECT TO CHANGE IF FURTHER INVESTIGATION REVEALS THAT THEY ARE NOT REASONABLE OR THAT THEY ARE BASED ON INACCURATE INFORMATION.

SIGNED: Curtis Chene  
NAME (PRINT): Curtis A. Chene

SIGNED: \_\_\_\_\_  
NAME (PRINT): \_\_\_\_\_

**\*\*NOTE\*\*** PLEASE PROVIDE A COPY OF THIS RECAP WITH YOUR DRAINAGE SUBMITTAL.