



City of Albuquerque Stormwater Construction Site Inspection Report

General Information

ESC File No.	B10E003C3B	Project Name:	McDonald's 30-0260
NPDES Id. No.	NMRI006BQ	Location:	9500 Universe Blvd NW
7/18/2024	Owner	Contractor	
Operator	McDonald's USA, LLC	Barnsley Construction LLC	
Contact name & title	Alex Breeden	Dan Barnsley	
e-mail	alex.breeden@us.mcd.com	dan@barnsleyconstruction.com	
Contact Phone #	630-207-0289	505-264-0251	
COA Inspector	Chancellor English	Start/End Time:	2:30pm
Construction Phase:	verticals, utilities		
Type of Inspection:	<input checked="" type="checkbox"/> Regular	<input type="checkbox"/> Storm Event	<input type="checkbox"/> Post Storm Event >0.25" <input type="checkbox"/> 311/Complaint <input type="checkbox"/> Follow Up
Weather at time of inspection?	Clear	Temperature: ~	40
Estimated date of last storm 0.25" or greater	12/22/2023		
Item Number	Deficiency/ Corrective Action		
1	The self-inspection reports are not being sent to the superintendent and were not available at the time of inspection in violation of CGP Part 4.7.3. Required mitigation: You must keep a copy of all inspection reports at the site or at an easily accessible location, so that they can be made immediately available at the time of an on-site inspection per CGP Part 4.7.3.		
2.1	Discharge off site? (Y/N)	no	
4	Self Inspection Reports	No	Latest report Date: N/A

Notes:	

City of Albuquerque Stormwater Inspector Signature and date: 7/23/2024
Contact information: Chancellor English (505) 924-3325
cenglish@cabq.gov

Chancellor English