

# CITY OF ALBUQUERQUE

*Planning Department*  
Alan Varela, Director



*Mayor Timothy M. Keller*

June 24, 2022

Jeffery Wooten, P.E.  
Wooten Engineering  
1005 21<sup>st</sup> St SE, Suite A5  
Rio Rancho, NM 87124

**Re: Dutch Brothers Coffee**  
**Tract 8, Ventana Square – Universe Blvd. NW**  
**Request for Certificate of Occupancy - Permanent**  
**Grading and Drainage Plan Stamp Date: 7/30/21**  
**Certification dated: 6/21/2022**  
**Drainage File: B10D003I**

Dear Mr. Wooten,

PO Box 1293

Based on the Certification received 6/23/22 and site visit 6/23/22, this certification is approved in support of Permanent Certificate of Occupancy by Hydrology.

Albuquerque

If you have any questions, you can contact me at 924-3986 or [earmijo@cabq.gov](mailto:earmijo@cabq.gov).

NM 87103

Sincerely,

[www.cabq.gov](http://www.cabq.gov)

Ernest Armijo, P.E.  
Principal Engineer, Planning Dept.  
Development Review Services



# City of Albuquerque

Planning Department  
Development & Building Services Division

## DRAINAGE AND TRANSPORTATION INFORMATION SHEET (REV 11-2018)

**Project Title:** Dutch Bros Coffee **Building Permit #:** \_\_\_\_\_ **Hydrology File #:** \_\_\_\_\_  
**DRB#:** \_\_\_\_\_ **EPC#:** \_\_\_\_\_ **Work Order#:** \_\_\_\_\_  
**Legal Description:** Tract H-8, Ventana Square at Ventana Ranch  
**City Address:** Not Yet Assigned

**Applicant:** Wooten Engineering **Contact:** Jeffrey T. Wooten, P.E.  
**Address:** PO Box 15814, Rio Rancho, NM 87174  
**Phone#:** 505-980-3560 **Fax#:** N/A **E-mail:** jeffwooten.pe@gmail.com

**Owner:** \_\_\_\_\_ **Contact:** \_\_\_\_\_  
**Address:** \_\_\_\_\_  
**Phone#:** \_\_\_\_\_ **Fax#:** \_\_\_\_\_ **E-mail:** \_\_\_\_\_

**TYPE OF SUBMITTAL:** \_\_\_\_\_ PLAT (\_\_\_\_ # OF LOTS) \_\_\_\_\_ RESIDENCE \_\_\_\_\_ DRB SITE ☒ ADMIN SITE

**IS THIS A RESUBMITTAL?:** \_\_\_\_\_ Yes ☒ No

**DEPARTMENT:** \_\_\_\_\_ TRAFFIC/ TRANSPORTATION ☒ HYDROLOGY/ DRAINAGE

Check all that Apply:

### TYPE OF SUBMITTAL:

- ☒ ENGINEER/ARCHITECT CERTIFICATION
- ☐ PAD CERTIFICATION
- ☐ CONCEPTUAL G & D PLAN
- ☐ GRADING PLAN
- ☐ DRAINAGE MASTER PLAN
- ☐ DRAINAGE REPORT
- ☐ FLOODPLAIN DEVELOPMENT PERMIT APPLIC
- ☐ ELEVATION CERTIFICATE
- ☐ CLOMR/LOMR
- ☐ TRAFFIC CIRCULATION LAYOUT (TCL)
- ☐ TRAFFIC IMPACT STUDY (TIS)
- ☐ OTHER (SPECIFY) \_\_\_\_\_
- ☐ PRE-DESIGN MEETING?

### TYPE OF APPROVAL/ACCEPTANCE SOUGHT:

- ☐ BUILDING PERMIT APPROVAL
- ☒ CERTIFICATE OF OCCUPANCY
- ☐ PRELIMINARY PLAT APPROVAL
- ☐ SITE PLAN FOR SUB'D APPROVAL
- ☐ SITE PLAN FOR BLDG. PERMIT APPROVAL
- ☐ FINAL PLAT APPROVAL
- ☐ SIA/ RELEASE OF FINANCIAL GUARANTEE
- ☐ FOUNDATION PERMIT APPROVAL
- ☐ GRADING PERMIT APPROVAL
- ☐ SO-19 APPROVAL
- ☐ PAVING PERMIT APPROVAL
- ☐ GRADING/ PAD CERTIFICATION
- ☐ WORK ORDER APPROVAL
- ☐ CLOMR/LOMR
- ☐ FLOODPLAIN DEVELOPMENT PERMIT
- ☐ OTHER (SPECIFY) \_\_\_\_\_


**DATE SUBMITTED:** June 21, 2022 **By:** Jeffrey T. Wooten, P.E.

COA STAFF:

ELECTRONIC SUBMITTAL RECEIVED: \_\_\_\_\_

FEE PAID: \_\_\_\_\_





UNIVERSE BLVD. NE (R/W VARIES)

CAUTION - NOTICE TO CONTRACTOR  
THE CONTRACTOR IS SPECIFICALLY CAUTIONED THAT THE LOCATION AND/OR ELEVATION OF EXISTING UTILITIES AS SHOWN ON THESE PLANS IS BASED ON RECORDS OF THE VARIOUS UTILITY COMPANIES AND, WHERE POSSIBLE, MEASUREMENTS TAKEN IN THE FIELD. THE INFORMATION IS NOT TO BE RELIED ON AS BEING EXACT OR COMPLETE. THE CONTRACTOR MUST CALL THE APPROPRIATE UTILITY COMPANY AT LEAST 48 HOURS BEFORE ANY EXCAVATION TO REQUEST EXACT FIELD LOCATION OF UTILITIES. IT SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR TO RELOCATE ALL EXISTING UTILITIES WHICH CONFLICT WITH THE PROPOSED IMPROVEMENTS SHOWN ON THE PLANS.

- LEGEND**
- FLOW ARROW
  - 27.8 PROPOSED TOP OF GRADE/PVMT ELEVATIONS
  - FL27.8 PROPOSED FLOW LINE/GUTTER ELEVATIONS
  - TC27.8 PROPOSED TOP OF CURB ELEVATIONS
  - TS27.8 PROPOSED TOP OF SIDEWALK ELEVATION
  - FGH83.40 FINISHED GRADE AT TOP OF WALL
  - FGL83.40 FINISHED GRADE AT BOTTOM OF WALL
  - 515 EXISTING CONTOUR
  - 515 PROPOSED CONTOUR
  - EXISTING STORM DRAIN

#### DRAINAGE MANAGEMENT PLAN

**INTRODUCTION**  
The purpose of this submittal is to provide a final grading plan for the subject site located on Tract H, Ventana Square near the NEC of Paseo Del Norte Blvd and Universe Blvd in Albuquerque, NM. The overall development contains approximately 0.95 acres. The site was previously undeveloped and is now being developed into a new Dutch Bros Coffee building. The recently approved Drainage Report for the Master Planned Development can be found in Hydrology File B10/D003C3 and was prepared by Thompson Engineering Consultants, Inc.

**EXISTING HYDROLOGIC CONDITIONS**  
The site currently drains from northwest to southeast and into an existing drainage pond on the north side of Paseo Del Norte Blvd. This pond is being improved by the aforementioned Drainage Report by Thompson Engineering Consultants, Inc.

**PROPOSED HYDROLOGIC CONDITIONS**  
The proposed Dutch Bros Coffee site will continue to drain from northwest to southeast and into the improved pond proposed by the Thompson Engineering Consultants, Inc. report. All drainage is via surface flow; however, we are proposing to implement new Stormwater Quality Ponds within the Dutch Bros Coffee property that will not only help to capture pollutants, they will also still the stormwater flows exiting the site.


**CONCLUSION**  
This drainage management plan conforms to the approved Drainage Report prepared by Thompson Engineering Consultants, Inc. and with the City of Albuquerque DPM. With this submittal, we are requesting Building Permit approval.

#### DRAINAGE CERTIFICATION

I, JEFFREY T. WOOTEN, NMPE 16892, OF THE FIRM WOOTEN ENGINEERING, HEREBY CERTIFY THAT THIS PROJECT HAS BEEN GRADED AND WILL DRAIN IN SUBSTANTIAL COMPLIANCE WITH AND IN ACCORDANCE WITH THE DESIGN INTENT OF THE APPROVED PLAN DATED 7/30/2021. THE RECORD INFORMATION EDITED ONTO THE ORIGINAL DESIGN DOCUMENT HAS BEEN OBTAINED BY CHRISTOPHER A. MEDINA, NMPS 15702, OF THE FIRM TERRA LAND SURVEYS LLC. I FURTHER CERTIFY THAT I PERSONALLY VISITED THE PROJECT SITE ON 6/20/2022 AND HAVE DETERMINED BY VISUAL INSPECTION THAT THE SURVEY DATA PROVIDED IS REPRESENTATIVE OF ACTUAL SITE CONDITIONS AND IS TRUE AND CORRECT TO THE BEST OF MY KNOWLEDGE AND BELIEF. THIS CERTIFICATION IS SUBMITTED IN SUPPORT OF A REQUEST FOR PERMANENT CERTIFICATE OF OCCUPANCY.

THE RECORD INFORMATION PRESENTED HEREON IS NOT NECESSARILY COMPLETE AND INTENDED ONLY TO VERIFY SUBSTANTIAL COMPLIANCE OF THE GRADING AND DRAINAGE ASPECTS OF THIS PROJECT. THOSE RELYING ON THIS RECORD DOCUMENT ARE ADVISED TO OBTAIN INDEPENDENT VERIFICATION OF ITS ACCURACY BEFORE USING IT FOR ANY OTHER PURPOSE.

JEFFREY T. WOOTEN, NMPE 16892



#### VICINITY MAP

#### LEGAL DESCRIPTION:

Tract H-8, Ventana Square at Ventana Ranch, 0.95 Acres.



#### FIRM MAP 35001C0103H

Per Firm Map 35001C0103H, dated August 16, 2012, the site is not located in the Floodplain and determined to be outside the 0.2% chance Annual Floodplain.

#### GRADING NOTES

- EXCEPT AS PROVIDED HEREIN, GRADING SHALL BE PERFORMED AT THE ELEVATIONS AND IN ACCORDANCE WITH THE DETAILS SHOWN ON THIS PLAN.
- THE COST FOR REQUIRED CONSTRUCTION DUST AND EROSION CONTROL MEASURES SHALL BE INCIDENTAL TO THE PROJECT COST.
- ALL WORK RELATIVE TO FOUNDATION CONSTRUCTION, SITE PREPARATION, AND PAVEMENT INSTALLATION, AS SHOWN ON THIS PLAN, SHALL BE CONSTRUCTED IN ACCORDANCE WITH THE "GEOTECHNICAL INVESTIGATION," AS PROVIDED BY THE ARCHITECT OR OWNER. ALL OTHER WORK SHALL, UNLESS OTHERWISE SPECIFIED OR PROVIDED FOR HEREON, BE CONSTRUCTED IN ACCORDANCE WITH THE PROJECT, (FIRST PRIORITY) SPECIFICATIONS, AND/OR THE CITY OF ALBUQUERQUE (COA) STANDARD SPECIFICATIONS FOR PUBLIC WORKS (SECOND PRIORITY).
- EARTH SLOPES SHALL NOT EXCEED 3 HORIZONTAL TO 1 VERTICAL UNLESS SHOWN OTHERWISE.
- IT IS THE INTENT OF THESE PLANS THAT THIS CONTRACTOR SHALL NOT PERFORM ANY WORK OUTSIDE OF THE PROPERTY BOUNDARIES EXCEPT AS REQUIRED BY THIS PLAN.
- THE CONTRACTOR IS TO ENSURE THAT NO SOIL ERODES FROM THE SITE ONTO ADJACENT PROPERTY OR PUBLIC RIGHT-OF-WAY. THIS SHOULD BE ACHIEVED BY CONSTRUCTING TEMPORARY BERM OR SILT FENCE AT THE PROPERTY LINES AND WETTING THE SOIL TO PROTECT IT FROM WIND EROSION.
- A DISPOSAL SITE FOR ANY & ALL EXCESS EXCAVATION MATERIAL, AND UNSUITABLE MATERIAL AND/OR A BORROW SITE CONTAINING ACCEPTABLE FILL MATERIAL SHALL BE OBTAINED BY THE CONTRACTOR IN COMPLIANCE WITH APPLICABLE ENVIRONMENTAL REGULATIONS AND APPROVED BY THE OBSERVER. ALL COSTS INCURRED IN OBTAINING A DISPOSAL OR BORROW SITE AND Haul TO OR FROM SHALL BE CONSIDERED INCIDENTAL TO THE PROJECT AND NO SEPARATE MEASUREMENT OR PAYMENT SHALL BE MADE.
- PAVING AND ROADWAY GRADES SHALL BE +/- 0.05' FROM PLAN ELEVATIONS. PAD ELEVATION SHALL BE +/- 0.05' FROM BUILDING PLAN ELEVATION.
- ALL PROPOSED CONTOURS AND SPOT ELEVATIONS REFLECT TOP OF PAVEMENT ELEVATIONS IN THE PARKING AREA AND MUST BE ADJUSTED FOR PAVEMENT, MEDIANS, AND ISLANDS.
- VERIFY ALL ELEVATIONS SHOWN ON PLAN FROM BASIS OF ELEVATION CONTROL STATION (IF APPLICABLE) PRIOR TO BEGINNING CONSTRUCTION.
- THE CONTRACTOR SHALL PROVIDE THE SWPPP DOCUMENT (IF NECESSARY) AND SHALL ABIDE BY ALL LOCAL, STATE, AND FEDERAL LAWS, RULES AND REGULATIONS WHICH APPLY TO THE CONSTRUCTION OF THESE IMPROVEMENTS, INCLUDING EPA REQUIREMENTS WITH RESPECT TO STORM WATER DISCHARGE.

#### IMPERVIOUS AREA CALCULATIONS

##### PROPOSED SITE CONDITIONS

TOTAL SITE AREA: 41,215 SF  
PERVIOUS AREA: 11,477 SF (27.8%)  
IMPERVIOUS AREA: 29,738 SF (72.2%)

#### STORMWATER QUALITY POND CALCULATIONS

##### IMPERVIOUS AREAS

TOTAL NEW IMPERVIOUS AREAS = 29,738 SF  
SWQ VOLUME REQ'D = 29,738 \* 0.42" / 12 = 1,041 CF  
TOTAL VOLUME PROVIDED = 1,774 CF (3 POUNDS)

#### Proposed Drainage Calculations

Ultimate Development Conditions Basin Data Table

This table is based on the COA DPM Chapter 6.2, Zone: 1

BASIN	Area (SQ. FT.)	Area (AC.)	Land Treatment Percentages				Q(100) (cfs/ac.)	Q(100) (CFS)	WT E (inches)	V(100) <sub>360</sub> (CF)	V(100) <sub>1440</sub> (CF)	V(100) <sub>960</sub> (CF)
			A	B	C	D						
SITE	41215	0.95	0.0%	0.0%	27.0%	73.0%	3.97	3.75	1.71	5857	6860	9869
TOTAL	41215	0.95						3.75		5857	6860	9869

NO WORK SHALL BE PERFORMED IN THE PUBLIC RIGHT-OF-WAY WITHOUT AN APPROVED WORK ORDER OR EXCAVATION PERMIT.



#### BENCH MARK

ACS MONUMENT 13-B10  
PUB. EL.=5424.81 NAVD 1988

Dutch Bros  
NEQ Paseo Del Norte & Universe  
Albuquerque, NM 87114

Grading Plan

C-200