


CITY OF ALBUQUERQUE



March 26, 2009

Jeffrey G. Mortensen, P.E.
High Mesa Consulting Group
6010-B Midway Park Blvd. NE
Albuquerque, NM 87109

**Re: Chamisa Storm Drain Surge Pond- Work Order 662382-Record Drawing
Engineer's Stamp dated 11-26-08 (B10/D004)
Engineer's Certification 2-18-09**

Dear Mr. Mortensen,

PO Box 1293

Based upon the information provided in your submittal received 2-19-09, the above referenced plan is approved for a DPM Variance and Work Order Closeout by Hydrology for the following reasons:

Albuquerque

- The pond has excess capacity for the 100 yr-10 day storm.
- The spillway is an interim condition.
- If the spillway capacity is exceeded, there is no development that will be harmed.

NM 87103

If you have any questions, you can contact me at 924-3695.

www.cabq.gov

Sincerely,

Curtis A. Cherne, P.E.
Senior Engineer, Planning Dept.
Development and Building Services

C: file
Brad Bingham