


CITY OF ALBUQUERQUE



July 2, 2013

Vince Carrica, P.E.
Tierra West, LLC
5571 Midway Park Place NE
Albuquerque, NM 87109

**Re: Boulders Phase II Lots 58-78
Pad Certification Stamp Dated 6/28/2013
Engineer's Stamp Date 10/24/2012 (B11/D001C)**

Dear Mr. Carrica,

Based upon the information provided in your submittal received 6/28/2013, the above referenced Grading and Drainage Plan is accepted for pad Certification for lots 58-78.

Be advised, upon field verification for the pad sites, it appeared that the retaining wall behind lots 76 & 77 should be extended past lot 78. Lots 79 and 80 seemed to be 2 feet or more above lot 78.

PO Box 1293

If you have any questions, you can contact me at 924-3986 or Rudy Rael at 924-3977.

Albuquerque

New Mexico 87103

www.cabq.gov

Sincerely,

Curtis Cherne, P.E.
Principal Engineer, Planning Dept.
Development and Building Services

C: RR/CC
e-mail