


CITY OF ALBUQUERQUE



October 18, 2011

Gregory James Krenik, P.E.
Mark Goodwin and Associates
P.O. Box 90606
Albuquerque, NM 87199

Re: St. Jude Thaddeus Church, 5712 Paradise Blvd. NW
Request for C.O.—90 Day Temporary Approved
Engineer's Stamp dated: 10/14/10 (B-11/D003)
Certification dated: 10-13-11

Dear Mr. Krenik,

Based upon the information provided in your submittal received 10-14-11, the above referenced certification is approved for release of a 90 Day Temporary Certificate of Occupancy by Hydrology.

When submitting for Permanent CO please address the following comments:

- The pond volume should be certified.
- Due to the north and east sides of the retention pond being a 1:1 slope an engineered means of erosion control is required. Rock plating may be applicable in this application.

If you have any questions, you can contact me at 924-3986.

Sincerely,

Curtis Cherne, P.E.
Principal Engineer—Hydrology,
Development and Building Services

C: CO Clerk—Katrina Sigala
File

