



City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

September 6, 1995

**Tom Isaacson, PE
Isaacson & Arfman
128 Monroe Street NE
Albuquerque, NM 87108**

**RE: ENGINEER'S CERTIFICATION FOR ARROYO VILLAS APTS [REDACTED]
RECEIVED AUGUST 31, 1995 FOR CERTIFICATE OF OCCUPANCY
ENGINEER'S STAMP DATED 8-31-95**

Dear Mr. Isaacson:

Based on the information included in the submittal referenced above, City Hydrology accepts the Engineer's Certification of Buildings 1 & 2 at 4701 Irving NW for Certificate of Occupancy. Any further certification must address the following comments:

Indicate the limits of the phase that is certified. Identify any interim drainage improvements or erosion control measures required for the phasing. Provide sufficient spot elevations to verify that an adequate water block has been provided at each entrance.

If you have any questions about this project, You may contact me at 768-2727.

Sincerely,

**John P. Curtin, P.E.
Civil Engineer/Hydrology**

c: Andrew Garcia