


CITY OF ALBUQUERQUE

TO: Debbie Trujillo, High Mesa
from: Curtis Cherne 924-3695



September 5, 2008

Levi A. Trujillo, P.E.
Gualote Lane, Route 1 Box 10
Espanola, NM 87532

Re: Enchanted RV, ⁹⁶⁵⁴9500 Eagle Ranch Road NW
(B-13/D002E1)

Approval of Permanent Certificate of Occupancy

Engineer's Stamp Date 6/20/2008

Certification dated: 8-29-08

Mr. Trujillo:

PO Box 1293

Based upon the information provided in your submittal received 9/4/08, the above referenced certification is approved for release of Permanent Certificate of Occupancy by Hydrology.

Albuquerque

If you have any questions, you can contact me at 924-3695.

NM 87103

Sincerely,

Curtis A. Cherne, P.E.
Senior Engineer-Hydrology, Planning Dept
Development and Building Services

www.cabq.gov

C: CO Clerk—Katrina Sigala
file

DRAINAGE CERTIFICATION

I, LEVI A. TRUJILLO, NMPE #5692

HEREBY CERTIFY THAT THIS PROJECT HAS BEEN GRADED AND WILL DRAIN IN
SUBSTANTIAL COMPLIANCE WITH AND IN ACCORDANCE WITH THE DESIGN INTENT OF THE
APPROVED PLAN DATED 12/19/07 & ADMINISTRATIVE AMENDMENT DATED 3/27/08.
THE RECORD INFORMATION EDITED ONTO THE
ORIGINAL DESIGN DOCUMENT HAS BEEN OBTAINED BY ME OR UNDER MY DIRECT
SUPERVISION AND IS TRUE AND CORRECT TO THE BEST OF MY KNOWLEDGE AND BELIEF.
THIS CERTIFICATION IS SUBMITTED IN SUPPORT OF A REQUEST FOR
ENGINEER'S CERTIFICATION (HYDROLOGY)

CHANGES:

PER DISCUSSIONS WITH HYDROLOGY DEPARTMENT:

1. NO CISTERN NEEDED AND DELETED.
2. ADDITIONAL PONDING WEST SIDE PROPERTY.
3. EAST PONDING CHANGED TO STORM DRAIN USAGE.

THE RECORD INFORMATION PRESENTED HEREON IS NOT NECESSARILY COMPLETE AND
INTENDED ONLY TO VERIFY SUBSTANTIAL COMPLIANCE OF THE GRADING AND
DRAINAGE ASPECTS OF THIS PROJECT. THOSE RELYING ON THIS RECORD DOCUMENT
ARE ADVISED TO OBTAIN INDEPENDENT VERIFICATION OF ITS ACCURACY BEFORE USING
IT FOR ANY OTHER PURPOSE.

LEVI A. TRUJILLO NMPE #5692

DATE

8/29/08


APPROVED BY THE EXECUTIVE COMMITTEE ON 12/19/07
ADMINISTRATIVE AMENDMENT 3/27/08

Retention Pond Perimeter to
Slope 3:1 Scale and cover with
1" & 2" Cobbel Stone to Avoid Erosion
Any over flow of Pond can
Drain on to Eagle Ranch Rd.
Pond Design to meet 96
Hour Evaporation Code

Item #3 on proposed Grading
& Drainage Plan to Read
"Type d"

Existing Storm Drain 5060
Permeates @ Sidewalk Curb
Will slope to Storm Drain
@ 3:1
Area to be Filled with 1" & 2"
Cobble stone for landscape &
Erosion Protection.

- (A) 3 curb inlets to
be 2' in with to
Allow Drainage
(B) 2 curb inlets to
be 2' to allow drainage
onto landscape & continue
Flow to Storm Drain



RECEIVED
SEP 04 2008
HYDROLOGY
SECTION

