PLANS/PLATS ON FILE

FILE DESC: _____

B-13 / D003B

PLANS/PLATS 2

Address 9901 Coors Bld By Pmt MM Engr/Arch Charles Easterling
Plans Approved 12- 89 Plan 2-15-89 Cond.
Comments: (B-13/050) Add to Reliable Chevrolet

Tom Mattingly 897-6704

Inspection Requested 3-14-90/ Contractor MILLER-STAUCH CONST
Appr. 7/31/90 Disappr. 30 Day Temp. 30 TEMP ON 3-15-90
Comments: 30 TEMP FOR BLDG C
Certified by Engineer ON 7/31/90

DRAINAGE INFORMATION SHEET

PROJECT TITLE: RELIABLE CHEVROLET ZONE ATLAS/DRNG. FILE #: B-13/D38

LEGAL DESCRIPTION: PORTION TRACT N1-A SEVEN BAR RANCH

CITY ADDRESS: _____

ENGINEERING FIRM: TASTENLING & ASSOC CONTACT: DOUG CREWE

ADDRESS: 5643 ALBUQUERQUE BLVD NW 87114 PHONE: 898-8021

OWNER: _____ CONTACT: _____

ADDRESS: _____ PHONE: _____

ARCHITECT: PATRICK McCLERNON ARCH CONTACT: PAT McCLERNON

ADDRESS: 1901 5TH ST. NW 87102 PHONE: 242-5219

SURVEYOR: _____ CONTACT: _____

ADDRESS: _____ PHONE: _____

CONTRACTOR: _____ CONTACT: _____

ADDRESS: _____ PHONE: _____

RECEIVED
OCT 07 1988
HYDROLOGY SECTION

PRE-DESIGN MEETING:

___ YES
___ NO
___ COPY OF CONFERENCE RECAP SHEET PROVIDED

DRB NO. _____
EPC NO. E 85-79-3
PROJ. NO. _____

WP-905

TYPE OF SUBMITTAL:

___ DRAINAGE REPORT
___ DRAINAGE PLAN
X CONCEPTUAL GRADING & DRAINAGE PLAN
___ GRADING PLAN
___ EROSION CONTROL PLAN
___ ENGINEER'S CERTIFICATION

CHECK TYPE OF APPROVAL SOUGHT:

___ SKETCH PLAT APPROVAL
___ PRELIMINARY PLAT APPROVAL
X SITE DEVELOPMENT PLAN APPROVAL
___ FINAL PLAT APPROVAL
___ BUILDING PERMIT APPROVAL
___ FOUNDATION PERMIT APPROVAL
___ CERTIFICATE OF OCCUPANCY APPROVAL
___ ROUGH GRADING PERMIT APPROVAL
___ GRADING/PAVING PERMIT APPROVAL
___ OTHER _____ (SPECIFY)

DATE SUBMITTED: 10-7-88

BY: DOUG CREWE

FILE COPY

City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

KEN SCHULTZ
MAYOR

November 1, 1988

Doug Crewe
Easterling & Associates, Inc.
5643 Paradise Blvd., NW
Albuquerque, NM 87114

RE: CONCEPTUAL GRADING AND DRAINAGE PLAN SUBMITTAL OF RELIABLE CHEVROLET, RECEIVED OCTOBER 7, 1988, FOR SITE DEVELOPMENT PLAN APPROVAL. (B-13/D3B)

Dear Mr. Crewe:

The above referenced submittal dated 9/30/88 can not be approved until AMAFCA has approved the drainage scheme concerning how much of the runoff will be allowed to be diverted into the Calabacillas Arroyo through the existing temporary CMP outfall. In accordance with the approved Master Drainage Plan for the site, 9.7 cfs should be drained to the east into the existing storm drain provided for that purpose.

If you have any questions call me at 768-2650.

Cordially;

Roger A. Green, PE

Roger A. Green, P.E.
C.E./ Hydrology Section

xc. Cliff Anderson, AMAFCA

RAG/(WP+905)

DRAINAGE INFORMATION SHEET

PROJECT TITLE: RELIABLE CHEVY ZONE ATLAS/DRNG. FILE #: D-13/D38

LEGAL DESCRIPTION: PORTION TRACT N1-A SOUTH BAR RANCH

CITY ADDRESS: _____

ENGINEERING FIRM: EASTER, LUNA & ASSOC. CONTACT: DAVE CREUR

ADDRESS: 5643 PARADISE BLVD NW 87114 PHONE: 898-8021

OWNER: _____ CONTACT: _____

ADDRESS: _____ PHONE: _____

ARCHITECT: PATRICK McCLERNON DRCH CONTACT: PAT McCLERNON

ADDRESS: 1401 5TH ST NW 87102 PHONE: 242-5219

SURVEYOR: _____ CONTACT: _____

ADDRESS: _____ PHONE: _____

CONTRACTOR: _____ CONTACT: _____

ADDRESS: _____ PHONE: _____

RECEIVED
NOV 02 1988
HYDROLOGY SECTION

PRE-DESIGN MEETING:

___ YES
___ NO
___ COPY OF CONFERENCE RECAP SHEET PROVIDED

DRB NO. _____
EPC NO. Z 85-77-3
PROJ. NO. _____

TYPE OF SUBMITTAL:

___ DRAINAGE REPORT
___ DRAINAGE PLAN
X CONCEPTUAL GRADING & DRAINAGE PLAN
___ GRADING PLAN
___ EROSION CONTROL PLAN
___ ENGINEER'S CERTIFICATION

CHECK TYPE OF APPROVAL SOUGHT:

___ SKETCH PLAT APPROVAL
___ PRELIMINARY PLAT APPROVAL
X SITE DEVELOPMENT PLAN APPROVAL
___ FINAL PLAT APPROVAL
___ BUILDING PERMIT APPROVAL
___ FOUNDATION PERMIT APPROVAL
___ CERTIFICATE OF OCCUPANCY APPROVAL
___ ROUGH GRADING PERMIT APPROVAL
___ GRADING/PAVING PERMIT APPROVAL
___ OTHER _____ (SPECIFY)

DATE SUBMITTED: 11-1-88

BY: DAVE CREUR

DRAINAGE INFORMATION SHEET

PROJECT TITLE: RELIABLE CHEVY ZONE ATLAS/DRNG. FILE #: B-13/D3B

LEGAL DESCRIPTION: PORTION TRACT D1-A SUNN DAR RANCH

CITY ADDRESS: _____

ENGINEERING FIRM: BOHANNAN HUSTON INC. CONTACT: DOUG CROWE

ADDRESS: 5643 PARADISE BLVD NW PHONE: 898-8021

OWNER: _____ CONTACT: _____

ADDRESS: _____ PHONE: _____

ARCHITECT: PATRICK McCLERNON CONTACT: PAT McCLERNON

ADDRESS: 1401 5TH ST NW PHONE: 242-5219

SURVEYOR: _____ CONTACT: _____

ADDRESS: _____ PHONE: _____

CONTRACTOR: _____ CONTACT: _____

ADDRESS: _____ PHONE: _____

PRE-DESIGN MEETING:

___ YES
___ NO
___ COPY OF CONFERENCE RECAP SHEET PROVIDED

RECEIVED
DEC 09 1988
HYDROLOGY SECTION

DRB NO. 86-0527
EPC NO. Z 85-79-3
PROJ. NO. _____

TYPE OF SUBMITTAL:

___ DRAINAGE REPORT
X DRAINAGE PLAN
___ CONCEPTUAL GRADING & DRAINAGE PLAN
X GRADING PLAN
___ EROSION CONTROL PLAN
___ ENGINEER'S CERTIFICATION

CHECK TYPE OF APPROVAL SOUGHT:

___ SKETCH PLAT APPROVAL
___ PRELIMINARY PLAT APPROVAL
___ SITE DEVELOPMENT PLAN APPROVAL
___ FINAL PLAT APPROVAL
X BUILDING PERMIT APPROVAL
___ FOUNDATION PERMIT APPROVAL
___ CERTIFICATE OF OCCUPANCY APPROVAL
___ ROUGH GRADING PERMIT APPROVAL
___ GRADING/PAVING PERMIT APPROVAL
___ OTHER _____ (SPECIFY)

DATE SUBMITTED: 12-8-88

BY: Doug Crowe

FILE COPY

City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

KEN SCHULTZ
MAYOR

December 16, 1988

Doug Crewe
Easterling & Associates, Inc.
5643 Paradise Blvd., NW
Albuquerque, NM 87114

RE: GRADING AND DRAINAGE PLAN SUBMITTAL OF RELIABLE CHEVROLET, RECEIVED DECEMBER 9, 1988, FOR BUILDING PERMIT APPROVAL. (B-13/D3B)

Dear Mr. Crewe:

The above referenced submittal dated 12-9-88 can not be approved for the following reasons:

1. It is not consistent with the drainage scheme of the approved Conceptual Grading and Drainage Plan. No cover letter was provided to explain this change.
2. Show the location of the "Prudent Line" on the plan view.
3. Show the basin boundaries for basin Area A, and have the lines match those shown in the legend.
4. Show the required pipe size for the new drain on the north side of the building addition.
5. Provide a TBM near the project site.
6. A License Agreement from AMAFCA will be required for any storm drain structures within the arroyo "Prudent Line". If a structure is approved by AMAFCA then a storm drain manhole is required on the "Prudent Line".

If you have any questions call me at 768-2650.

Cordially;

Roger A. Green, PE

Roger A. Green, P.E.
C.E./ Hydrology Section

xc: Cliff Anderson, AMAFCA

RAG/(WP+903)

AN EQUAL OPPORTUNITY EMPLOYER

R. WARD MUNNICUTT, CHAIRMAN
PAT D. HIGDON, VICE-CHAIRMAN
REX FUNK, SECRETARY-TREASURER
DANIEL W. COOK, DIRECTOR
RONALD D. BROWN, DIRECTOR

LARRY A. BLAIR
EXECUTIVE ENGINEER

Albuquerque
Metropolitan
Arroyo
Flood
Control
Authority

2600 PROSPECT N.E. - ALBUQUERQUE, N. M. 87107
TELEPHONE (505) 884-2215

RECEIVED FEB 10 1989

February 9, 1989

Chuck Easterling
Easterling & Associates, Inc.
5643 Paradise Blvd. NE
Albuquerque, New Mexico 87114

RECEIVED
FEB 21 1989
HYDROLOGY SECTION

RE: V.T. Inc. Autopark - Grading and Drainage Plan and Plan-Profile Details

Dear Chuck:

AMAFCA has reviewed the above referenced plans and present the following comments:

a. Sheet 2, Plan. Limits of construction should be identified. The area disturbed by construction must be reseeded and mulched with a gravel mulch (2 inches of 3/4 to 1-1/2 inch diameter gravel).

b. Sheet 2, Profile. The hydraulic grade line should be identified. The elevation of the outlet structure endsill should be specified. Is this endsill high enough to allow a hydraulic jump to occur within the structure at maximum flow conditions? Reference to City of Albuquerque Standard Details and Specifications should be included.

c. Sheet 2, Outlet Structure Detail. Is the reinforcment #5 at 12 inches on center, each way? What is the chamfer dimension? What kind of insert, retainer or keeper will keep the neopreme joint in place? Cutting the pipe flush with the outlet structure headwall should not be optional.

d. Sheet 2, General Notes. A note should be added to the plans requiring the contractor to contact AMAFCA not less than 2 working days prior to any construction activity on AMAFCA's easement area. AMAFCA's prudent line easement should be clearly identified on the plans (Sheets 1 and 2).

All of this construction will require a Agreement Encroachment License approved by AMAFCA's Board of Directors. AMAFCA's next Board meeting is scheduled for February 23, 1989. A draft of a Agreement Encroachment License is enclosed.

Sincerely,
AMAFCA

Clifford E. Anderson, PE & LS
Drainage Engineer

cc: Fred Aguirre, Hydrologist, City of Albuquerque PWD

Easterling & Associates, Inc.

5643 Paradise Boulevard, NW
Albuquerque, New Mexico 87114
(505) 898-8021

February 16, 1989

RECEIVED
FEB 21 1989
HYDROLOGY SECTION

Mr. Cliff Anderson
Drainage Engineer
AMAFCA
2600 Prospect, NE
Albuquerque, NM 87110

RE: DESIGN REVIEW COMMENTS, DATED FEBRUARY 9, 1989 -- VT, INC. AUTO PARK

Dear Cliff:

Thank you for your comments on the above-referenced plan. I offer the following responses for your consideration:

a. Sheet 2, Plan. The limits of disturbance have been identified. Seeding and gravel mulch will be applied to disturbed areas.

b. Sheet 2, Profile. The hydraulic grade line has been added. The endsill elevation has been added. The basin approximates a Burec Type II basin and should contain the hydraulic jump. Its hydraulic characteristics, in a 100-year event, are as follows:

V_{inlet} = 22 fps	Jump height over endsill = 1.5'
Q = 21 cfs	Tw depth = 1.0 + 1.5 = 2.5'
D_1 = 1.0'	Length of jump ≅ 3 x Tw ≅ 7.5'
Froude No. = 3.1	

Reference to City of Albuquerque Standard Details and Specifications was already made in the general notes.

c. Sheet 2, Outlet Structure Detail. Reinforcing steel spacing is #5 bars, 12" on center, both ways. A 1/2" radius chamfer has been shown. We have shown a press seal water stop gasket around the end of the pipe to form a key as the concrete is poured around it.

d. Sheet 2, General Notes. AMAFCA notification note has been added and prudent line easement identified.

If I can be of further assistance in this matter, please do not hesitate to contact me.

Sincerely,

Charles M. Easterling, P.E.

CME/dlh
Job No. 2193

Enclosures: Revised plan sheets

cc: Mr. Pat McClernon w/enclosures: Copy of letter, Revised plan sheets

Easterling & Associates, Inc.

5643 Paradise Boulevard, NW
Albuquerque, New Mexico 87114
(505) 898-8021

February 17, 1989

Roger Green, P.E.
Hydrology Section
City of Albuquerque
P.O. Box 1293
Albuquerque, NM 87103

RECEIVED
FEB 21 1989
HYDROLOGY SECTION

RE: B-13/D3B, RELIABLE CHEVROLET (VT AUTO PARK IN SEVEN BAR RANCH)

Dear Roger:

This letter is to inform you that the changes made to the approved conceptual grading and drainage plan for VT Auto Park constitute an amendment to that plan. During final design, it was decided to discharge the site directly to the Calabacillas Arroyo, instead of collecting flows in existing facilities, due to site plan constraints and the availability of free discharge in the Calabacillas.

Enclosed are copies of letters from AMAFCA, with their comments regarding the design, and Easterling & Associates, Inc.'s response.

Should you have any questions, please do not hesitate to call.

Cordially,

Douglas E. Crewe

DEC/dlh
Job No. 2193

Enclosures

DRAINAGE INFORMATION SHEET

PROJECT TITLE: RELIABLE CHEVROLET ZONE ATLAS/DRNG. FILE #: B-13/D3B

LEGAL DESCRIPTION: PORTION OF TRACT M1-A SOUTH PAR RANCH

CITY ADDRESS: —

ENGINEERING FIRM: ESTERLINA ! ASSOC INC CONTACT: DAVE CREWE

ADDRESS: 5643 PARADISE BLVD NW PHONE: 898-8021

OWNER: _____ CONTACT: _____

ADDRESS: _____ PHONE: _____

ARCHITECT: PATRICK McCLERNON CONTACT: PATRICK McCLERNON

ADDRESS: 1401 5TH ST NW PHONE: 242-5219

SURVEYOR: _____ CONTACT: _____

ADDRESS: _____ PHONE: _____

CONTRACTOR: _____ CONTACT: _____

ADDRESS: _____ PHONE: _____

PRE-DESIGN MEETING:

___ YES
___ NO
___ COPY OF CONFERENCE RECAP SHEET PROVIDED

RECEIVED
FEB 21 1989
HYDROLOGY SECTION

DRB NO. _____
EPC NO. Z 85-79-3
PROJ. NO. _____

TYPE OF SUBMITTAL:

___ DRAINAGE REPORT
X DRAINAGE PLAN
___ CONCEPTUAL GRADING & DRAINAGE PLAN
X GRADING PLAN
___ EROSION CONTROL PLAN
___ ENGINEER'S CERTIFICATION

CHECK TYPE OF APPROVAL SOUGHT:

___ SKETCH PLAT APPROVAL
___ PRELIMINARY PLAT APPROVAL
___ SITE DEVELOPMENT PLAN APPROVAL
___ FINAL PLAT APPROVAL
X BUILDING PERMIT APPROVAL
___ FOUNDATION PERMIT APPROVAL
___ CERTIFICATE OF OCCUPANCY APPROVAL
___ ROUGH GRADING PERMIT APPROVAL
___ GRADING/PAVING PERMIT APPROVAL
___ OTHER _____ (SPECIFY)

DATE SUBMITTED: 2 · · 89

BY: DAVE CREWE

FILE COPY

City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

KEN SCHULTZ, MAYOR

CLARENCE V. LITHGOW, CHIEF ADMINISTRATIVE OFFICER

DAN WEAKS, DEPUTY CAO PUBLIC SERVICES

FRED E. MONDRAGON, DEPUTY CAO DEVELOPMENT & ENTERPRISE SERVICES

March 3, 1989

Charles M. Easterling
Easterling & Associates, Inc.
5643 Paradise Boulevard, NW
Albuquerque, New Mexico 87120

RE: REVISED DRAINAGE PLAN FOR RELIABLE CHEVROLET
(B-13/D3B) REVISION DATE OF FEBRUARY 15, 1989

Dear Mr. Easterling:

Based on the information provided on your resubmittal of February 21, 1989, the referenced drainage plan is approved for Building Permit.

Prior to Building Permit release, we will need concurrence from AMAFCA that the proposed work within their right of way is satisfactory. Also, please be advised that prior to Certificate of Occupancy release, we will need concurrence from AMAFCA for the work done within their right of way.

Please attach a copy of this approved plan to the construction sets prior to sign-off by Hydrology.

If I can be of further assistance, please feel free to call me at 768-2650.

Cordially,

Bernie J. Montoya, C.E.
Engineering Assistant

BJM/bsj
(WP+905)

DRB 86-527

Note: This plan does not match site plan prepared 11/13/89. Owner will update drawing for Building permit and that the drawing plan will be approved with prepared site plan 11/13/89

DRAINAGE INFORMATION SHEET

PROJECT TITLE: V.T. INC, AUTO PARK RELIABLE CHEVROLET HOONI ZONE ATLAS/DRNG. FILE #: B-13 / D33

LEGAL DESCRIPTION: TRACT N-1A-1 SEVEN BAR RANCH (LOTS 8 & 9)

CITY ADDRESS: 9901 COORS ROAD NW

ENGINEERING FIRM: EASTERLING & ASSOC. CONTACT: DAVID SMITH

ADDRESS: 5643 PARADISE BLVD. NW PHONE: 898 8021

OWNER: V.T. INC. (ATTN. RICK MATHEWS) CONTACT: RICK MATHEWS

ADDRESS: 9901 COORS ROAD NW PHONE: 898 6700

ARCHITECT: PATRICK McCLERNON CONTACT: PATRICK McCLERNON

ADDRESS: 1901 FIFTH ST. NW., ABQ PHONE: 242 5219

SURVEYOR: COMMUNITY SCIENCES CORP. CONTACT: LINWOOD CARLETON

ADDRESS: BOX 1328, CORRALES NM 87048 PHONE: 897-0000

CONTRACTOR: MILLER-STEVICH CONTACT: TOM MATTAMORE

ADDRESS: 9901 COORS RD. NW. PHONE: 897-0704

PRE-DESIGN MEETING:

___ YES

___ NO

___ COPY OF CONFERENCE RECAP SHEET PROVIDED

DRB NO. 89-142

EPC NO. _____

PROJ. NO. _____

TYPE OF SUBMITTAL:

___ DRAINAGE REPORT

___ DRAINAGE PLAN

___ CONCEPTUAL GRADING & DRAINAGE PLAN

X GRADING PLAN

___ EROSION CONTROL PLAN

___ ENGINEER'S CERTIFICATION

CHECK TYPE OF APPROVAL SOUGHT:

___ SKETCH PLAT APPROVAL

___ PRELIMINARY PLAT APPROVAL

___ SITE DEVELOPMENT PLAN APPROVAL

___ FINAL PLAT APPROVAL

X BUILDING PERMIT APPROVAL

___ FOUNDATION PERMIT APPROVAL

___ CERTIFICATE OF OCCUPANCY APPROVAL

___ ROUGH GRADING PERMIT APPROVAL

___ GRADING/PAVING PERMIT APPROVAL

___ OTHER _____ (SPECIFY)

RECEIVED
DEC 11 1989
HYDROLOGY SECTION

DATE SUBMITTED: 12/11/89

BY: PATRICK McCLERNON CMP

FILE COPY

City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

KEN SCHULTZ
MAYOR

December 20, 1989

Charles M. Easterling
Easterling & Associates, Inc.
5643 Paradise Boulevard, NW
Albuquerque, New Mexico 87120

RE: REVISED DRAINAGE PLAN FOR RELIABLE CHEVROLET
(B-13/D3B) REVISION DATE OF DECEMBER 8, 1989

Dear Mr. Easterling:

Based on the information provided on your resubmittal of December 11, 1989, the referenced drainage plan is approved for building permit.

Please attach a copy of this approved plan to the construction sets prior to sign-off by Hydrology.

Prior to Certificate of Occupancy release, the following is required:

1. Concurrence from AMAFCA for the construction done within their right-of-way; and

2. Engineer's Certification per the D.P.M. checklist.

If I can be of further assistance, please feel free to call me at 768-2650.

Cordially,

Bernie J Montoya

Bernie J. Montoya, C.E.
Engineering Assistant

BJM/bsj
(WP+905)

DRAINAGE INFORMATION SHEET

ZONE ATLAS/DRAINAGE FILE NO. B-13/D33

PROJECT TITLE: RELIABLE CHEVROLET

LEGAL DESCRIPTION: PORTION OF TRACT H1-A SOUTH BARR RANCH

CITY ADDRESS:

ENGINEERING FIRM: Easterling & Assoc. Inc. CONTACT:

ADDRESS: 5643 Paradise Blvd. N.W. PHONE: 898-8021

OWNER: RELIABLE CHEVROLET CONTACT: RICK MATHEWS

ADDRESS: PHONE: 897-6000

ARCHITECT: PAT McCLERNON CONTACT:

ADDRESS: 1401 5TH ST. NW PHONE: 242-5219

SURVEYOR: CONTACT:

ADDRESS: PHONE:

CONTRACTOR: MILLER-STROCH CONTACT:

ADDRESS: 8500 W. 63RD SUIT. 20 PHONE:
MERRIAM KS 66202

PRE-DESIGN MEETING:

____ YES
____ NO
____ COPY OF CONFERENCE RECAP SHEET PROVIDED

DRB NO.:
EPC NO. 285-79-3
PROJECT NO.:

TYPE OF SUBMITTAL:

____ DRAINAGE REPORT
__X__ DRAINAGE PLAN
____ CONCEPTUAL GRADING & DRAINAGE PLAN
__X__ GRADING PLAN
____ GRADING & DRAINAGE PLAN
____ EROSION CONTROL PLAN
__X__ ENGINEER'S CERTIFICATION

CHECK TYPE OF APPROVAL SOUGHT:

____ SKETCH PLAT APPROVAL
____ PRELIMINARY PLAT APPROVAL
____ SITE DEVELOPMENT PLAN APPROVAL
____ FINAL PLAT APPROVAL
____ BUILDING PERMIT APPROVAL
____ FOUNDATION PERMIT APPROVAL
__X__ CERTIFICATE OF OCCUPANCY APPROVAL
____ ROUGH GRADING PERMIT APPROVAL
____ GRADING/PAVING PERMIT APPROVAL
____ OTHER (SPECIFY)

RECEIVED
JUL 19 1990
HYDROLOGY DIVISION

DATE SUBMITTED: 7-19-90 BY: DOUG CREWE

FILE COPY

City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

August 1, 1990

Charles Easterling
Easterling & Associates, Inc.
5643 Paradise Boulevard, NW
Albuquerque, New Mexico 87114

RE: ENGINEER'S CERTIFICATION FOR RELIABLE CHEVROLET
(B-13/D3B) ENGINEER'S STATEMENT DATED JULY 18, 1990

Dear Mr. Easterling:

Based on the information provided on your submittal of July 19, 1990, Engineer's Certification is acceptable for the referenced site.

If I can be of further assistance, please feel free to call me at 768-2650.

Cordially,

for Bernie J. Montoya
Fred J. Aguirre, P.E.
Hydrologist

BJM:FJA/bsj
(WP+905)

PLAN/PLATS

ON

FILE