



City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

October 8, 1993

Bob Ryals, P.E.
Ryals Engineering
4929 Idlewilde SE
Albuquerque, N.M. 87108

RE: GRADING & DRAINAGE PLAN FOR KEN JOHNS WESTSIDE PHASE 2C (B-13/D4A)
RECEIVED OCTOBER 4, 1993 FOR GRADING PERMIT APPROVAL
ENGINEER'S STAMP DATED 10/1/93

Dear Mr. Ryals:

Based on the information included in the submittal referenced above, City Hydrology APPROVES this project for Grading Permit.

Make certain that the Contractor receives a copy of this updated plan. The top of curb above the grate should be corrected from 47.92 to 48.92 first.

A separate permit is required for construction of private drainage facilities within the City right-of-way. A copy of this letter must be on hand when applying for the excavation permit. City Hydrology will send the sidewalk inspector his copy of the plan.

Engineer's Certification of grading & drainage per DPM checklist must be approved before the Certificate of Occupancy will be released.

If you have any questions about this project, you may contact me at 768-2727.

Sincerely,

John P. Curtin, P.E.
Civil Engineer/Hydrology

xc: Alan Martinez
Darlene Saavedra
File

WPHYD/7879

PUBLIC WORKS DEPARTMENT

