

City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

December 28, 1995

Mark Goodwin, P.E. Mark Goodwin & Assoc. P. O. Box 90606 Albuquerque, NM 87199

RE:

ENGINEER'S CERTIFICATION FOR TRAILS WEST SUBDIVISION (B-13/D6C) RECEIVED DECEMBER 18, 1995 FOR FINANCIAL GUARANTY RELEASE ENGINEER'S STAMP DATED 12/14/95

Dear Mr. Goodwin:

Based on the information included in the submittal referenced above, City Hydrology has the following comments that must be addressed:

City Hydrology requires as-built elevations for every pad or FF. As-built elevations are also required at every other corner of each lot. Top of curb elevations may be used on the street side of the lot. This is the minimum as-built elevation requirement.

If You have any questions about this project, You may contact me at 768-2727.

Sincerely,

John P. Curtin, P.E.

Civil Engineer/Hydrology

c: Andrew Garcia

Rick Davis, Family Housing Dev Corp, 1114 Pennsylvania NE 87110