

# CITY OF ALBUQUERQUE



September 5, 2006

837-9877

G. Robert Adams, P.E.  
Adams Engineering  
500 Nolen Dr., Suite 550  
South Lake, Texas 76092

**Re: McDonalds 1600 Alameda NW, Grading and Drainage Plan**  
**Engineer's Stamp dated 8-28-06 (B14/D14)**

Dear Mr. Adams,

Based upon the information provided in your submittal dated 9-1-06, the above referenced plan is approved for Building Permit. Please attach a copy of this approved plan to the construction sets prior to sign-off by Hydrology.

Prior to Certificate of Occupancy release,

- Add a drain to the trash enclosure. Drainage from trash enclosures is required to be conveyed to the sanitary sewer.
- Engineer Certification per the DPM checklist will be required.

This project requires a National Pollutant Discharge Elimination System (NPDES) permit. If you have any questions feel free to call the Municipal Development Department Hydrology Section at 768-3654 (Charles Caruso).

If you have any questions, you can contact me at 924-3695.

Sincerely,

Curtis A. Cherne, E.I.  
Engineering Associate, Planning Dept.  
Development and Building Services  
CLB

C: file  
Charles Caruso, DMD