



City of Albuquerque Stormwater Construction Site Inspection Report

General Information

Project Name:	Larry H. Miller Hyuandai				
Location:	9820 Coors Blvd.				
Site Contact Name & Agency	Nathan Maarsala - LHM H.	ESC File No.	B14E014		
	nathan.maarsala@lhm.com	NPDES Id. No.	NMR10028B		
Inspection Date:	08/21/19	Start/End Time:	0845/0850		
CoA Stormwater Inspector:	Timothy E. Sims				
Construction Phase:	grading & C&G				
Type of Inspection:	☐ Regular	☐ Storm Event	☐ Post Storm Event >0.25"	☒ 311/Complaint	☐ Follow Up

Weather at time of inspection?	Clear	Temperature: ~	75*
Estimated date of last storm 0.25" or greater	7/7/2019		

Item Number	Deficiency/ Corrective Action		
	all previous issues resolved; no new issues observed with this inspection		
	Please provide the latest SWPPP self-inspection report (inspections should be within 14 days)		
2.1	Discharge off site? (Y/N)	No	
4	Self Inspection Reports	requested	Latest report Date: 7/31/2019

Notes:	

City of Albuquerque Stormwater Inspector Signature and date:
Contact information: Timothy E. Sims - (505) 803-6155
tsims@cabq.gov 08/21/19