

CITY OF ALBUQUERQUE



June 26, 2019

Cassandra Durkin, CPESC
Inspections Plus Inc.
504 El Paraiso Rd NE, Suite B
Albuquerque, NM 87113

**Re: Larry H. Miller Hyundai
Erosion and Sediment Control Plan
CPESC's Stamp Date 6-19-19 (B14E017)**

Dear Ms. Durkin,

Based upon the information provided in your submittal received 6-25-19, the above referenced plan is not approved to be included in the SWPPP and for NOI documentation review for grading until the following comments are addressed:

Since half of this site is in the City and the other half is not in the City, comments on the ESC plan will be limited to the portion of the site in the City limits.

PO Box 1293

1. Show the jurisdictional line on the plan.
2. Provide inlet protection for the proposed inlet in the northern pond.
3. Vehicle Tracking Control is not addressed on the plan.

Albuquerque

The City is providing recommendations for BMPs outside the city limits. Since this portion of the site is outside City limits, these items are not required to be shown on the plan, but may help your client be in compliance.

NM 87103

1. Provide inlet protection for the proposed inlet in the southern pond.
2. Propose sediment BMP at the eastern edge of the disturbance.

www.cabq.gov

If you have any questions, you can contact me at 924-3420.

Sincerely,

Curtis Cherne, P.E.
Principal Engineer, Stormwater Quality
Planning Dept.

C: email