

# CITY OF ALBUQUERQUE

Hydrology Section Planning Department  
Brennon Williams, Director



Timothy M. Keller, Mayor

January 10, 2020

Gama Development, LLC. – Brian McCarthy [Brian@Abrazohomes.com](mailto:Brian@Abrazohomes.com)

Site: Ascension Subdivision – 8814 Horizon - B17E006


**Re: Drainage Ordinance (14-5-2-1) Violations for Erosion and Sediment Control**

Dear Mr. McCarthy

The following violations were observed at the inspection two days ago.

1. The east silt fence has a hole near the north end and sediment offsite there and near the southeast corner in the vicinity of the offsite curb and inlets.
2. Track-out at the north entrance.

These photos were taken two days ago:



PO Box 1293

Albuquerque

New Mexico 87103

[www.cabq.gov](http://www.cabq.gov)







# CITY OF ALBUQUERQUE

Hydrology Section Planning Department  
Brennon Williams, Director



Timothy M. Keller, Mayor



## Required Mitigation:

1. Initiate maintain of stormwater controls immediately upon identification of the need and complete such work by the end of the next business day.
2. Implement additional track-out controls to insure that sediment is removal occurs prior to vehicle exit.
3. Where sediment has been tracked-out onto paved areas outside your site remove and dispose of sediment by the end of the same business day.

If the violations are not mitigated within 7 days, the property owner is subject to a fine of \$500/day per the City's Drainage Control Ordinance.

If you have any questions, you can contact me at 924-3420 or [jhughes@cabq.gov](mailto:jhughes@cabq.gov).

Sincerely,

James D. Hughes, P.E.  
Principal Engineer, Hydrology/Stormwater Quality  
Planning Dept.

PO Box 1293

Albuquerque

New Mexico 87103

[www.cabq.gov](http://www.cabq.gov)

