

# CITY OF ALBUQUERQUE



June 27, 2016

Diane Hoelzer, P.E.  
Mark Goodwin and Associates  
P.O. Box 90606  
Albuquerque, NM 87199

**Re: Glendesto Subdivision  
Erosion and Sediment Control Plan  
Engineer's Stamp Date 6-14-16 (B18E020)**

Dear Ms. Hoelzer,

Based upon the information provided in your submittal received 6-17-16 the above referenced plan is approved to be included in the SWPPP and to apply for an ESC Permit for grading and for Building Permit.

The plan is also approved for Preliminary Plat action by the DRB.

However, the plan cannot be approved to be included in the Work Order Construction plans until the following comments are addressed:

1. Sections of Modesto Ave and/or Glendale Ave. will have to be graded and paved. Provide BMPs for this work.
2. Most projects require utility cuts for water and sewer. Appropriate BMPs are required.
3. Include longitudinal street slopes on the plan.

If you have any questions, you can contact me at 924-3420.

Sincerely,

Curtis Cherne, P.E.  
Principal Engineer, Stormwater Quality  
Planning Dept.

PO Box 1293

Albuquerque

New Mexico 87103

[www.cabq.gov](http://www.cabq.gov)