



# City of Albuquerque Stormwater Construction Site Inspection Report

## General Information

ESC File No.	B18E028	Project Name:	Burger King		
NPDES Id. No.	NMR100463	Location:	2110 Carlisle Blvd. NE		
2/28/2022	Owner	Contractor			
Operator	Auto Nation USA	Rycon Construction Inc			
Contact name & title	Fred Moss	Michael Burns			
e-mail	<a href="mailto:mossf@autonation.com">mossf@autonation.com</a>	<a href="mailto:mburns@ryconinc.com">mburns@ryconinc.com</a>			
Contact Phone #	954-769-2303	263-6965			
COA Inspector	Doug Hughes	Start/End Time:	4pm		
Construction Phase:	Excavation/grading				
Type of Inspection:	<input checked="" type="checkbox"/> Regular	<input type="checkbox"/> Storm Event	<input type="checkbox"/> Past Storm Event >0.25"	<input type="checkbox"/> 311/Complaint	<input type="checkbox"/> Follow Up
Weather at time of inspection?		clear		Temperature: ~	60
Estimated date of last storm 0.25" or greater		2/2/2022			
Item Number	Deficiency/ Corrective Action				
1	The SWPPP wasn't available onsite, and there was no indication onsite as to its location. The up-to-date SWPPP must be available onsite.				
2					
3					
4					
5					
6					
2.1	Discharge off site? (Y/N)	No			
4	Self Inspection Reports		Latest report Date:		

Notes:	
Foundation footings excavated and steel in the trench, but no washout container on site.	
The area of land disturbing activities has been increased to include the two lots adjacent to San Pedro, so the SWPPP map and NOI need to be revised, to update the SWPPP.	

City of Albuquerque Stormwater Inspector Signature and date:  
Contact information: Doug Hughes (505-924-3420)  
[jhughes@cabq.gov](mailto:jhughes@cabq.gov)