

# CITY OF ALBUQUERQUE



May 21, 2018

David Soule, P.E.  
Inspections Plus Inc.  
805 Nikanda Rd NE  
Albuquerque, NM 87107

**Re: Estates at Glendale Ph III-Ashton Homes  
Erosion and Sediment Control Plan  
Engineer's Stamp Date 5-7-18 (B19E027)**

Dear Mr. Soule,

Based upon the information provided in your submittal received 5-7-18, the above referenced plan is approved to be included in the SWPPP and to apply for an ESC Permit for grading and Building Permit with the following condition:

1. A sediment BMP (cutback behind the curb, silt fence or mulch sock is required behind the curb on every lot.

PO Box 1293

If you have any questions, you can contact me at 924-3420.

Albuquerque

Sincerely,

NM 87103

Curtis Cherne, P.E.  
Principal Engineer, Stormwater Quality  
Planning Dept.

[www.cabq.gov](http://www.cabq.gov)

C: email