

# CITY OF ALBUQUERQUE



October 10, 2012

John M. MacKenzie, P.E.  
**Mark Goodwin & Associates, P.A.**  
P.O. Box 90606  
Albuquerque, NM 87199

**Re: Estates @ Glendale, Lots 1 & 2,**  
**Grading Plan for Pad Certification—Accepted**  
**Engineer's Stamp date 07-13-12 (B19/D027)**  
**Certification date 10-09-12**

Dear Mr. MacKenzie,

PO Box 1293

Based upon the information provided in your submittal received 10-09-12, the above referenced Certification is accepted for Building Permits.

Albuquerque

Please address the following comments prior to additional certifications for this subdivision.

NM 87103

1. The curb along the south side of Glendale, from the west property line to the inlet, will need completion.
2. Completion on the retaining wall at the south end of Twilight Lane requires completion.
3. Twilight will require asphalt pavement.
4. Please certify the pond volume.

www.cabq.gov

If you have any questions, you can contact me at 924-3999.

Sincerely,

Richard Dourte, P.E.  
City Engineer—Planning Dept.  
Development and Building Services

Copy: e-mail  
file