

CITY OF ALBUQUERQUE



July 25, 2012

D. Mark Goodwin, P.E.
Mark Goodwin & Associates, P.A.
P.O. Box 90606
Albuquerque, NM 87199

mark@goodwinengineers.com

**Re: The Estates at Glendale Unit 1, Lots 2,
Grading Certification—Not Accepted
Engineer's Stamp date 07-13-12 (B19/D027)
Certification date 07-23-12**

Dear Mr. Goodwin,

PO Box 1293

Based upon the information provided in your submittal received 07-24-12, the above referenced Certification is unacceptable for Grading Certification for Building Permits.

Albuquerque

1. Lot 2 appears to lack proper grades to adhere to the design intent.
2. The temporary retention pond requires certification with this certification

NM 87103

If you have any questions, you can contact me at 924-3695.

www.cabq.gov

Sincerely,

Shahab Biazar, P.E.
Senior Engineer—Hydrology, Planning Dept.
Development and Building Services

Copy: e-mail
file