

CITY OF ALBUQUERQUE

Planning Department
Alan Varela, Director



Mayor Timothy M. Keller

May 12, 2025

Jackie McDowell, P.E.
McDowell Engineering, Inc.
7820 Beverly Hills Ave. NE
Albuquerque, NM 87122

RE: Jim Reimer II
8621 Glendale NE
Grading & Drainage Plan
Engineer's Stamp Date: 4/21/25
Hydrology File: B20D022
Case # HYDR-2025-00138

Dear Ms. McDowell:

Based upon the information provided in your submittal received 4/21/2025, the Grading & Drainage Plan **is not approved** for Building Permit. The following comments need to be addressed for approval of the above referenced project.


PO Box 1293

Albuquerque

NM 87103

www.cabq.gov

1. Per the IDO, the property owner of the property is responsible for building the adjacent half of Glendale Ave. NE to include curb & gutter, and sidewalk. **The project will have to go to the Development Facilitation Team (DFT) / Delvelopment Hearing Officer (DHO) for approval of the Infrastructure List and re-platting action.** Also, half of an 84" storm sewer (see below) will also need to added to the Infrastructure List. The storm sewer was called out in the NAA MDP.



2. These improvements will need to be shown on the Grading & Drainage Plan.

CITY OF ALBUQUERQUE

Planning Department
Alan Varela, Director



Mayor Timothy M. Keller

As a reminder, if the project total area of disturbance (including the staging area and any work within the adjacent Right-of-Way) is 1 acre or more, then an Erosion and Sediment Control (ESC) Plan and Owner's certified Notice of Intent (NOI) is required to be submitted to the Stormwater Quality Engineer (Doug Hughes, PE, jhughes@cabq.gov, 505-924-3420) 14 days prior to any earth disturbance.

If you have any questions, please contact me at 505-924-3314 or amontoya@cabq.gov.

Sincerely,



Anthony Montoya, Jr., P.E.
Senior Engineer, Hydrology
Planning Department, Development Review Services

PO Box 1293

Albuquerque

NM 87103

www.cabq.gov