

CITY OF ALBUQUERQUE
PLANNING DEPARTMENT
Hydrology Section
Predesign Meeting Conference Notes
DATE: 4-2-14

ZONE ATLAS PAGE: 20 B19 ADDRESS: _____

DRAINAGE FILE: N/A B200027

PROJECT SCOPE: subdivision on lots 6 and 7 south of
Glendale east of Barstow

ATTENDANCE: David Soule, Rita Harmon, Curtis Cherne

FINDINGS:

1. Development will be out of floodplain with a
Scour wall or outside of prudent line
2. ^{Developed} flows to Arroyo at or near existing flows
3. Developed flows to Glendale will have to be ^{managed} ~~managed~~
w/ a pipe or asphalt curb to pond at Barstow
4. Financially guarantee or build $\frac{1}{2}$ street section in
Glendale and storm drain per NAA DMD.

The undersigned agrees that the above findings are summarized accurately and are subject to change if further investigation reveals that they are not reasonable or that they are based on inaccurate information.

SIGNED: Curtis A. Cherne
NAME (PRINT): Curtis A. Cherne

SIGNED: DM
NAME (PRINT): David

NOTE: PLEASE INCLUDE A COPY OF THIS SHEET WITH YOUR DRAINAGE SUBMITTAL



