

CITY OF ALBUQUERQUE



December 7, 2011

David B. Thompson, P.E.
Thompson Engineering Consultants, Inc.
P.O. Box 65760
Albuquerque, NM 87193

Re: Cantata At The Trails, Pond J Grading Certification
Engineer's Stamp Date 8-09-11 (C09-D001B)

Dear Mr. Thompson,

Based upon the information provided in your submittal received 11-29-11, the above referenced plan can not be approved for certification until the following have been addressed.

PO Box 1293

Albuquerque

NM 87103

- The existing grades do not reflect the grades on the certification.
- There is approximately an eight foot vertical drop at the 48" storm drain pipe. The grades have to be sloped back or a section pipe may have to be added.
- Please provide a detail with elevations on the emergency spillway. It did not appear to have the wings at the two ends.

www.cabq.gov

If you have any questions, you can contact me at 924-3695.

Sincerely,

Shahab Biazar, P.E.
Senior Engineer, Planning Dept.
Development and Building Services

C: File