

City of Albuquerque Stormwater Construction Site Inspection Report

General Information

Project Name:	Taos II									
Location:	Hearhstone and Sandia Sunset									
Site Contact Name & Agency	Kevin Griffin				ESC File No.		C09E001G			
	DR Horton				NPDES Id. No.		NMR10012Z			
Inspection Date:	05/20/19		Start/End Time:		8:30/9:00					
CoA Stormwater Inspector:			Curtis Cherne							
Construction Phase:		vertical								
Type of Inspection:		Regular		Storm Event		Post Storm Event >0.25"		311/Complaint	X	Follow Up

Weather at time of inspection?	Cloudy	Temperature: ~	60
Estimated date of last storm 0.25" or greater	5/10/2019		

Item Number	Deficiency/ Corrective Action		
1	4 stucco wash-outs 9300 Sandia Sunset		
2	wash-out 9320 Sandia Sunset		
3	wash-out outside subdivision wash-out facility		
2.1	Discharge off site? (Y/N)	no	
4	Self Inspection Reports		Latest report Date: 4/16/2019

Notes:	
Subdivision washout to be maintained tomorrow.	

City of Albuquerque Stormwater Inspector Signature and date:
Contact information: Curtis Cherne PE 505-924-3420
ccherne@cabq.gov 05/20/

05/20/19

Auto a Chene