

CITY OF ALBUQUERQUE



November 1, 2016

David Soule, P.E.
Rio Grande Engineering
9171 Glendale Ave NE
Albuquerque, NM 87122

**Re: Taos II at the Trails Subdivision
Erosion and Sediment Control Plan
Engineer's Stamp Date 10-18-16 (C09E001G)**

Dear Mr. Soule,

Based upon the information provided in your submittal received 10-25-16 the above referenced plan is approved to be included in the SWPPP and to apply for an ESC Permit for grading and Building Permit.

The plan cannot be approved for Work Order since it does not show any BMPs for the widening of Paseo del Norte as shown on the approved Infrastructure List.

In addition, a haul road has been used in the Paseo del Norte ROW to deliver dirt to the site. It appears there is a low point near the east end of it which may act as a sediment basin. If drainage from the haul road makes it past (east) of this low-point, a sediment BMP shall be installed to prevent sediment from reaching Universe Blvd. See image attached to the e-mail for location of the haul road.

If you have any questions, you can contact me at 924-3420.

Sincerely,

Curtis Cherne, P.E.
Principal Engineer, Stormwater Quality
Planning Dept.

C: email