

# CITY OF ALBUQUERQUE



April 22, 2019

Yolanda Moyer, P.E.  
Bohannon Huston, Inc.  
7500 Jefferson St NE Courtyard 1  
Albuquerque, NM 87114

**Re: Durango Subd Units 3-5  
Erosion Sediment Control Plan  
Engineer's Stamp Date 4-16-19 (C09E012A)**

Dear Ms. Moyer,

Based upon the information provided in your submittal received 4-16-19, the above referenced plan is approved to be included in the SWPPP and for NOI documentation review for grading and Work Order approval with the following condition:

1. The storm drain inlets in Molas Road located at and downhill from the VTC will most likely require protection.

PO Box 1293

This project is not approved for earth disturbance, grading or Work Order until the EPA Notice of Intent (NOI) documentation has been reviewed and signed by the City.

Albuquerque

If you have any questions, you can contact me at 924-3420.

NM 87103

Sincerely,

Curtis Cherne, P.E.  
Principal Engineer, Stormwater Quality  
Planning Dept.

[www.cabq.gov](http://www.cabq.gov)