

# CITY OF ALBUQUERQUE



December 30, 2011

Daniel S. Aguirre, P.E.  
Wilson & Company, Inc.  
4900 Lang Ave. NE  
Albuquerque, NM 87109

**Re: Volcano Heights Drainage Compilation Report, Engineer's Stamp  
Dated 12-12-2011 (C10/D000)**


Dear Mr. Aguirre,

Based upon the information provided in your submittal received 12-12-11, the above referenced report is approved based on the following comments:

- Proposed discharge from Pond 2 is 470 cfs, and the total discharge from other Basins (4A, 4B, PDN2 ...) is 252 cfs. Therefore, the total discharge from these two locations is 722 cfs which exceeds the 620 cfs at AP1. The discharges from Basins 7, 12B, and A may have to be controlled discharges to meet the 620 cfs.
- Please see enclosed copy of the comments for SAD 228.

If you have any questions, you can contact me at 924-3695.

Sincerely,

  
Shahab Biazar, P.E.  
Senior Engineer, Planning Dept.  
Development and Building Services

C: File