

CITY OF ALBUQUERQUE



November 11, 2011

Daniel S. Aguirre, P.E.
Wilson & Company, Inc.
4900 Lang Ave. NE
Albuquerque, NM 87109

**Re: Volcano Heights Drainage Compilation Report, Engineer's Stamp
Dated 10-24-2011 (C10/D000)**

Dear Mr. Aguirre,

Based upon the information provided in your submittal received 10-25-11, the above referenced report is approved based on the following comments:

- | | |
|-------------|--|
| PO Box 1293 | • This report as you mentioned will serve only as a guide for allowable flows at a specific discharge points. |
| Albuquerque | • Detailed grading and drainage plans along with the necessary hydrology calculations are to be submitted as each area develops. |
| NM 87103 | • Provide design and details for any discharge to the Petroglyph National Monument to minimize erosion. |
| | • Same Basin Numbers to be used for drainage analysis of future developments within the limits of Volcano Heights Drainage Compilation Report. |

If you have any questions, you can contact me at 924-3695.

www.cabq.gov

Sincerely,

Shahab Biazar, P.E.
Senior Engineer, Planning Dept.
Development and Building Services

C: File