

City of Albuquerque Stormwater Construction Site Inspection Report

General Information

ESC File No.	C10E001A	Project Name:	Sonata Green			
NPDES Id. No.	NMR1003AC	Location:	Tree Line Ave. and Universe Blvd.			
5/25/2021	Owner		Contractor			
Operator	Sonata Green, LLC.		Wexford Construction			
Contact name & title	John Murtagh		JL Murtagh			
e-mail	jmurtagh@wcinm.com		JL@wcinm.com			
Contact Phone #	702-376-5287		505-259-3397			
COA Inspector	Thomas Evans		Start/End Time:	9:25 AM/10:05 AM		
Construction Phase:	Grading					
Type of Inspection:	Regular	Storm Event	Past Storm Event >0.25"	311/Complaint	Follow Up	
Weather at time of inspection?	clear		Temperature:	~ 67		
Estimated date of last storm 0.25" or greater	5/3/2021					
Item Number	Deficiency/ Corrective Action					
1	Silt fence down at NW corner of site. Re-install silt fences to prevent sediment from exiting the site.					
2	Maintain track-out pad.					
2.1	Discharge off site? (Y/N)		no			
4	Self Inspection Reports		Requested	Latest report Date:		

Notes:	Water trucks on site. Spoke with JL and Mike Webb about the silt fence and track-out pad. They are awaiting approval of permits to cut the curb at the northernmost entrance.

City of Albuquerque Stormwater Inspector Signature and date: 7
 Contact information: Thomas Evans (505-803-6215)
tevans@cabq.gov

Thomas Evans 05/26/2021