

## City of Albuquerque Stormwater Construction Site Inspection Report

General Information								
ESC File No.	C10E0	01A F	Project Name:		Sonata Green			
PDES Id. No. NMR10		05FW Location:			Tree Line Ave. and Universe Blvd.			
7/18/2024		Owner			Contractor			
Operator		Sonata Green, LLC.			Wexford Construction			
Contact name & title		John Murtagh			JL Murtagh			
e-mail		jmurtagh@wcinm.com			JL@wcinm.com			
Contact Phone #		702-376-5287			505-259-3397			
COA Inspector		Chancellor English			Start/End Time: 3pm			
Construction Phase:					erticals			
Type of Inspection:		Regular	Storm Event	Past Storm	Event >0.25"	311/Complaint	Follow Up	
Weather at time of i			clea	ſ		ature: ~	95	
Estimated date of last storm 0.25" or greater 6/30/202								
Item Number	Deficiency/ Corrective Action							
1	Required mitig	ation: You m tion in close p	ust post a sign or coroximity to the co	other notice nstruction si	of your permit of ite. The notice r	n violation of CGP coverage at a safe, must be located so site per CGP Part 1	publicly it is visible	
2.1	Discharge off site?	(Y/N)	no					
4	Self Inspect	ion Reports	yes	Latest re	port Date:	7/2/20	14	
	'	· ·			<u>.                                      </u>			
Notes:								
The SWPPP was in the construction office in one of the apartments near the leasing office.								

City of Albuquerque Stormwater Inspector Signature and date: 7/24/2024

Contact information: Chancellor English 505-924-3325

cenglish@cabq.gov

Chancellor English