



# City of Albuquerque Stormwater Construction Site Inspection Report

## General Information

ESC File No.	C11E004	Project Name:	Rosa Parks Stockpile Yard
NPDES Id. No.	NMR100501	Location:	Rosa Parks and Kimmick
4/11/2025, 5/1/2025	Owner	Contractor	
Operator	<a href="mailto:Steve.Metro@wilsonco.com">Steve.Metro@wilsonco.com</a> NMR100504	<a href="#">Guzman Construction</a>	
Contact name & title	Altagracia Pena NMR100501	Lupita Pena, NMR10042B	
e-mail	<a href="mailto:lupita@guzmancs.com">lupita@guzmancs.com</a>	<a href="mailto:lupita@guzmancs.com">lupita@guzmancs.com</a>	
Contact Phone #	505-341-8591	AP452-0663 SM280-4553	
COA Inspector	Chancellor English	Start/End Time:	2pm
Construction Phase:	Stockpiles and construction support		
Type of Inspection:	<input type="checkbox"/> Regular	<input type="checkbox"/> Storm Event	<input type="checkbox"/> Post Storm Event >0.25" <input type="checkbox"/> 311/Complaint <input checked="" type="checkbox"/> Follow Up
Weather at time of inspection?	Clear		Temperature: ~ 70
Estimated date of last storm 0.25" or greater	4/20/2025		

Item Number	Deficiency/ Corrective Action		
1	The perimeter silt fence needs replacement in violation of CGP Part 2.1.4. Required mitigation: Ensure all stormwater controls are maintained and remain in effective operating condition during the permit coverage and are protected from activities that would reduce their effectiveness per CGP Part 2.1.4.		
2	The SWPPP and inspection reports were unavailable (Same as paper) at the time of inspection in violation of CGP Parts 4.7.3 and 7.3. Require mitigation: You must keep a copy of your SWPPP and all inspection reports at the site or at an easily accessible location so that they can be made immediately available at the time of an on-site inspection per CGP Parts 4.7.3 and 7.3		
2.1	Discharge off site? (Y/N)	no	
4	Self Inspection Reports	No	Latest report Date: N/A

Notes:	QR code for SWPPP and Inspection reports.
Prior violations for Posting, SWPPP, BMPs, and stabilization	

City of Albuquerque Stormwater Inspector Signature and date: 5/5/2025  
Contact information: Chancellor English (505) 924-3325  
[cenglish@cabq.gov](mailto:cenglish@cabq.gov)

Chancellor English