

## **City of Albuquerque Stormwater Construction Site Inspection Report**

General Information							
ESC File No.	C12E	004 Project Name:		Kiddie Academy Westside			
NPDES Id. No.	NMR10	)0370 Lo	cation:	4590 Paradise Blvd. NW			
6/1/2021		Owner		Contractor			
Operator		Azaan Holdings			Snyder Construction		
Contact name & title					Benny Saiz		
e-mail					<u>bsaiz@snyder-const.com</u>		
Contact Phone #		501-256-9687			505-263-0961		
COA Inspector		Thomas Evans			Start/End Time: 11:55 AM/12:25 PM		
	ction Phase:				construction		
Type of Inspection:		Follow-up	Storm Event	Past Storm	Event >0.25"	311/Complaint	Follow Up
Weather at time of inspection? clear Temperature: ~						73	
Estimated date of last storm 0.25" or greater					5/31/2021		
Item Number	Deficiency/ Corrective Action						
2	Rasping debris and construction waste on the ground. Remove and dispose of construction waste in approved waste containers (CGP 2.3.3e). Remove rasping debris continuously with a vacuum and enclose the work area with plastic sheeting.						
3	NOI is not posted properly. Put signage of NOI permit coverage outside the perimeter fence in a location clearly visible to the public.						
4	Updated SWPPP not on site. Keep the updated SWPPP with inspection reports onsite and readily accessible.						
2.1	Discharge off site?	(Y/N)	no				
4	Self Inspec	tion Reports	Requested	Latest re	port Date:	8/27/20	020

Notes: Rasping debris located both along the building and outside the building near the entrance.

The updated SWPPP is still not on site. Benny said 814 Solutions is still working on it. The NOI was posted on the back of the 814 Solutions sign and placed at the construction entrance, not visible to the public. I directed Benny to move the sign to the NE corner of the site, and the crew did it by the time I left.

City of Albuquerque Stormwater Inspector Signature and date:

Contact information: Thomas Evans (505-803-6215)

tevans@cabq.gov

Thomas Evans

06/07/2021