



City of Albuquerque Stormwater Construction Site Inspection Report

General Information

ESC File No.	C12E004	Project Name:	Kiddie Academy Westside		
NPDES Id. No.	NMR100370	Location:	4590 Paradise Blvd. NW		
3/6/2023	Owner	Contractor			
Operator	Azaan Holdings	Snyder Construction			
Contact name & title	Aleem Hasham	Benny Saiz			
e-mail	aleemhasham@kiddieacademy.net	bsaiz@snyder-const.com			
Contact Phone #	501-256-9687	505-263-0961			
COA Inspector	Doug Hughes	Start/End Time:	1:30pm		
Construction Phase:	Building construction				
Type of Inspection:	<input checked="" type="checkbox"/> Follow-up	<input type="checkbox"/> Storm Event	<input type="checkbox"/> Past Storm Event >0.25"	<input type="checkbox"/> 311/Complaint	<input type="checkbox"/> Follow Up
Weather at time of inspection?		clear		Temperature: ~ 62	
Estimated date of last storm 0.25" or greater		12/4/2022			
Item Number	Deficiency/ Corrective Action				
2	none				
3					
4					
2.1	Discharge off site? (Y/N)	no			
4	Self Inspection Reports	<input checked="" type="checkbox"/> Requested	Latest report Date:	8/11/2022	

Notes:

There still isn't any significant growth of perennial vegetation. The mulch is still OK at 16 months old. You must continue permit coverage, self-inspections, SWPPP and BMP maintenance until the City determines that the Final Stabilization Criteria CGP2.2.14.c has been satisfied. Then you must remove the BMPs and send documentation of the Final Stabilization to the EPA with a Notice of Termination (NOT) per CGP 8.2 to end your coverage under the CGP. This step is independent of the Certificate of Occupancy. Please copy me with the documentation and the EPA's acceptance of the NOT.

City of Albuquerque Stormwater Inspector Signature and date:
Contact information: Doug Hughes (505-924-3420)
jhughes@cabq.gov

3/10/2023

James D. Hughes