

CITY OF ALBUQUE

Planning Department
Brennon Williams, Director



Mayor Timothy M. Keller

August 28, 2020
Gaylen Barnett
Eight14 Solutions
5750 Pino Ave NE
Albuquerque, NM 87109

Re: Kiddie Academy Westside – 4590 Paradise Blvd. Mulberry SE
Erosion and Sediment Control Plan
Engineer's Stamp Date: 8/26/2020 (C12E004)

Dear Ms. Barnett,

Based upon the information provided in your submittal received 8/26/2020, the above referenced plan is approved to be included in the SWPPP and to apply for an ESC Permit/eNOI for Grading and Building Permit.

The EPA Notice of Intent (NOI) documentation has been reviewed and signed by the City and is attached, so this project is approved for Grading and Building Permit.

Please include a copy of the approved plan along with a signed copy of the NOI in the Building Permit application.

If you have any questions, you can contact me at 924-3420 or jhughes@cabq.gov.

Sincerely,

James D. Hughes

James D. Hughes, P.E.
Principal Engineer, Planning Dept.
Development and Review Services