

## TREVESTON ELLIOTT AR-

811 12TH STREET NW  
ALBUQUERQUE NM 87102

o 505.246.9608

www TEarchitect.com

### PROJECT:

#### Valley View

9368 Valley View Drive NW  
Traffic Circulation Layout

### Response to review dated July 9, 2021

1. Not sure what this note is referring to: Number of spaces is per IDO
2. Corrected- internal C&G only
3. Added
4. Corrected
5. They are
6. They are
7. They sidewalk ramps are part of CoA std. dwg 2425 (noted on plan)  
Dimensions added and graphic changed to reflect dwg 2425
8. See drawing
9. See #5 detail
10. See drawing
11. See drawing
12. See Fire-1 Attached
13. All keyways are 5' min.
14. See sidewalk connection - exact entrances to buildings has not been  
designed- the entire frontage is accessible.
15. Ramps will be part of sidewalk from Accessible Aisle
16. There are no Vehicle to wheel chair conflict-
17. Sidewalk is on property line / noted / noted on detail #2
18. Added Bumpers-  
per IDO 7-%(k)(4)5. Vehicles may overhang walkways and  
landscape areas as long as the over- hang does not  
negatively impact the proposed landscape or reduce the  
required pedestrian access route to less than 4 feet wide.
19. Attached
20. Asphalt Parking Area called out on plan
21. Driveway Entrance Called out- not sure where else you need them
22. Mini Work Order
23. Noted
24. Noted
25. Noted
26. -
27. see attached