

# CITY OF ALBUQUERQUE



August 15, 2014

Philip Clark, P.E.  
Clark Consulting Engineers  
19 Ryan Road  
Edgewood, NM 87015

**Re: Indian Cycle Dealer, Grading and Drainage Plan  
Engineer's Stamp Date 8-13-14 (C17D002A22)**

Dear Mr. Clark,

Based upon the information provided in your submittal received 8-13-14, the above referenced plan is approved for Grading and Paving Permit with the following conditions:

1. The 6 inch pipes are to extend through the CMU wall and the openings around the pipes grouted.
2. The grade of the dirt at the northwest corner of the pond is to be at or above the water surface elevation (01) and two blocks are to be removed from the wall at the 01 or top of dirt elevation for an emergency spillway.

It is at the Engineer's discretion whether a certification is submitted for informational purposes.

If you have any questions, you can contact me at 924-3986.

Sincerely,

Curtis Cherne, P.E.  
Principal Engineer, Hydrology.  
Planning Dept.

C: e-mail