

**From:** [Bruce Stidworthy](#)  
**To:** [Matthew Satches](#)  
**Cc:** [Harmon Rita T.](#); [Cherne, Curtis](#)  
**Subject:** Re: Sportsplex Weir  
**Date:** Monday, November 03, 2014 11:48:07 AM  
**Attachments:** [image001.jpg](#)  
[image002.jpg](#)

---

Curtis, just to clarify a bit more we were thinking we would put a valley gutter where the existing curb and gutter is located and then slope the turn lane towards the valley gutter and put a water block at the driveway. That's how we have done most turn right turn lanes including some within DOT right-of-way.

On Nov 3, 2014, at 11:44 AM, Matthew Satches <[msatches@bhinc.com](mailto:msatches@bhinc.com)> wrote:

I'll have the revised grading plan delivered this afternoon with the changes discussed.

As for the deceleration lane, we intend to have the drainage remain in the DOT ROW. We'll show a water block on our plans. More details will be provided once we are past the conceptual stages and submit to the DOT for formal review.

Thanks,

Matt Satches  
Bohannon Huston, Inc.  
Community Development and Planning

---

**From:** Harmon Rita T. [<mailto:rharmon@cabq.gov>]  
**Sent:** Monday, November 03, 2014 10:55 AM  
**To:** Matthew Satches  
**Subject:** RE: Sportsplex Weir

Looks good to me, go ahead and update the first sheet with the detail change as well as the other 2 changes we discussed ( the rail and the footing tow on one side of the property line.)

So that we can better understand the drainage of the decel lane, show spot elevations or contours. Indicate a water block.

Thanks,  
Rita

---

**From:** Matthew Satches [<mailto:msatches@bhinc.com>]  
**Sent:** Monday, November 03, 2014 10:50 AM  
**To:** Harmon Rita T.

**Subject:** RE: Sportsplex Weir

The dimensions are correct, here's a slight update to reflect the steeper slope.

---

**From:** Harmon Rita T. [<mailto:rharmon@cabq.gov>]

**Sent:** Monday, November 03, 2014 10:36 AM

**To:** Matthew Satches

**Subject:** RE: Sportsplex Weir

Matthew,

Are the dim's. correct? One side of the sloped concrete wall is 3' wide, and the other is 6', but they look symmetrical. Can you draw to scale.

---

**From:** Matthew Satches [<mailto:msatches@bhinc.com>]

**Sent:** Monday, November 03, 2014 10:28 AM

**To:** Harmon Rita T.

**Subject:** RE: Sportsplex Weir

I've attached a PDF. The distance from the property line to bottom of pond is approximately 15'. This PDF has been revised to reflect accurate dimensions.

---

**From:** Harmon Rita T. [<mailto:rharmon@cabq.gov>]

**Sent:** Monday, November 03, 2014 10:06 AM

**To:** Matthew Satches

**Subject:** RE: Sportsplex Weir

Matthew,

I can't read the dimensions. What is distance from the 15' from property line to bottom of pond. Can you turn the image to a PDF.

---

**From:** Matthew Satches [<mailto:msatches@bhinc.com>]

**Sent:** Monday, November 03, 2014 10:03 AM

**To:** Harmon Rita T.; Cherne, Curtis

**Cc:** Bruce Stidworthy

**Subject:** Sportsplex Weir

Good Morning Curtis and Rita,

Would this weir configuration work? The rip rap was relocated to within the weir on our side of the property.

<image001.jpg>

Thanks,

**Matt Satches, E.I.**

Engineer Intern

Community Development & Planning

**Bohannan**<image002.jpg>**Huston**

Courtyard I

7500 Jefferson St. NE

Albuquerque, NM 87109-4335

[www.bhinc.com](http://www.bhinc.com)

**voice:** 505.823.1000 **facsimile:** 505.798.7988 **toll free:** 800.877.5332

DISCLAIMER: This e-mail, including attachments, may include confidential and/or proprietary information, and may be used only by the person or entity to which it is addressed. Any unauthorized review, use, disclosure or dissemination is strictly prohibited. If you received this e-mail in error, please notify the sender by reply e-mail and delete this e-mail immediately.