

CITY OF ALBUQUERQUE



March 23, 2012

Steven K. Marrow, P.E.

stevem@brasherlorenz.com

Brasher & Lorenz Consulting Engineers

2201 San Pedro NE Bldg 1 Ste. 1300

Albuquerque, NM 87110

**Re: 8324 Washington Street NE,
Request for Permanent C.O. - Disapproved
Engineer's Stamp dated: 01-17-12, (C17/D012)
Certification dated: 03-14-12**

Dear Mr. Morrow,

Based upon the information provided in the Certification received 03-14-12, the above referenced Certification is disapproved for release of a Permanent Certificate of Occupancy by Hydrology.

PO Box 1293

The onsite swale will need to discharge into the existing onsite inlet. Additional grading is required to achieve positive drainage to this inlet. Include the grate elevation and edge of asphalt, (west of the grate), at the fence line with the next certification.

Albuquerque

If you have any questions, you can contact me at 924-3695.

NM 87103

Sincerely,

Shahab Biazar, P.E.

Senior Engineer, Planning Dept.

Development and Building Services

www.cabq.gov

C: File