



City of Albuquerque Stormwater Construction Site Inspection Report

General Information

ESC File No.	C17E119	Project Name:	Horizon Village		
NPDES Id. No.	NMR10023E/NMR10023F	Location:	8814 Horizon Blvd.		
6/15/2021	Owner	Contractor			
Operator	Clearbrook Investments	Stillbrooke Homes			
Contact name & title	Chris Kelsey				
e-mail	ckelsey@stillbrooke.com				
Contact Phone #	858-1800				
COA Inspector	Thomas Evans	Start/End Time:	9:45 AM-9:50 AM		
Construction Phase:	idle				
Type of Inspection:		Storm Event	Past Storm Event >0.25"	311/Complaint	Follow Up
Weather at time of inspection?	clear	Temperature: ~		80	
Estimated date of last storm 0.25" or greater	5/31/2021				
Item Number	Deficiency/ Corrective Action				
1	No posting of permit coverage. Post NOI permit coverage in a location clearly visible to the public. The location of the SWPPP must also be identified on the sign.				
2	Sediment in the street. Sweep and remove sediment in the street.				
3	Silt fences are down or missing (south cul-de-sacs). Maintain silt fences.				
4	Areas of the site are not stabilized.				
2.1	Discharge off site? (Y/N)	no			
4	Self Inspection Reports	Requested	Latest report Date:	8/21/2020	

Notes:	No activity on site during this inspection.

City of Albuquerque Stormwater Inspector Signature and date:
Contact information: Thomas Evans (505-803-6215)
tevans@cabq.gov

Thomas Evans 06/17/2021