



City of Albuquerque Stormwater Construction Site Inspection Report

General Information

ESC File No.	C18E075	Project Name:	Stillbrook @ Sevano Place Subdivision		
NPDES Id. No.	NMR1003UE	Location:	6300 Alameda Blvd. NE		
10/25/2021	Owner	Contractor			
Operator	Stillbrooke Homes	Stillbrooke Homes			
Contact name & title	Chris Kelsey	Chris Kelsey			
e-mail	ckelsey@stillbrooke.com	ckelsey@stillbrooke.com			
Contact Phone #	505-858-1800	505-858-1800			
COA Inspector	Doug Hughes	Start/End Time:	4pm		
Construction Phase:	Vertical				
Type of Inspection:		Storm Event	Past Storm Event >0.25"	311/Complaint	Follow Up
Weather at time of inspection?		clear	Temperature: ~		73
Estimated date of last storm 0.25" or greater		9/30/2021			
Item Number	Deficiency/ Corrective Action				
1	Concrete/stucco Washout on the ground and no containers.				
2	The up-to-date SWPPP was not available onsite				
3	NPDES Posting doesn't include StillBrook ID # NMR1003UE.				
2.1	Discharge off site? (Y/N)	no			
4	Self Inspection Reports	Requested	Latest report Date:	10/25/2021	

Notes:	

City of Albuquerque Stormwater Inspector Signature and date:
Contact information: Doug Hughes 924-3420
jhughes@CABQ.gov

10/26/2021
James D. Hughes