



INSPECTION REPORT

GENERAL INFORMATION

DATE OF INSPECTION: 3/2/2021

COMPANY NAME: Sevano Development, LLC

PROJECT NAME: Sevano Place Subdivision

LOCATION: Sevano Loop, Albuquerque, New Mexico, 87113

TRACKING NO: NMR10039R, NMR10039X, NMR1003B0

COMPLIANCE EVALUATION: Marginal

TYPE OF INSPECTION: 14Day

START TIME: 2:26 PM

END TIME: 2:42 PM

INSPECTOR'S NAME: Ray Welton

INSPECTOR'S TITLE: NPDES Inspector

INSPECTOR'S QUALIFICATIONS: StormwaterONE

INSPECTOR'S CONTACT: 505-400-7500

PHASE OF CONSTRUCTION: Clear and Grub Excavation Building (vertical)
 Rough Grading Infrastructure Final Grading
 Final Stabilization

WEATHER INFORMATION

HAS A STORM EVENT OCCURRED SINCE THE LAST INSPECTION? Yes No

WEATHER AT TIME OF THIS INSPECTION: Clear

TEMPERATURE: 57

HAVE ANY DISCHARGES OCCURRED SINCE THE LAST INSPECTION? Yes No

ARE ANY DISCHARGES OCCURRING NOW? Yes No

ARE ANY PORTIONS OF YOUR SITE UNSAFE TO INSPECT? Yes No

POLLUTION PREVENTION, SEDIMENT AND EROSION CONTROL BMP'S

#	S&E/P2 CONTROLS	MAINTENANCE	CORRECTIVE ACTION	LOCATION	QUANTITY	UNIT	PHOTO
1	NPDES Permit Notification	None	None	Signal Ave	1	EA	Yes
2	NPDES Permit Notification	None	None	Signal Ave	1	EA	Yes
3	Construction Entrance	None	None	Signal Ave Entrance	1	EA	Yes
4	Silt Fence	None	None	Signal Ave Perimeter	150	LF	Yes
5	Concrete Washout	Clean	None	Onsite	1	EA	Yes
6	Debris or Waste	Remove	None	Onsite	1	EA	Yes

GENERAL SITE INSPECTION ITEMS

#	INSPECTION ITEM	INSPECTOR'S OBSERVATION	ACTION REQUIRED?	NOTES
1	Is the SWPPP signage clearly posted with the correct information and properly displayed at an obvious perimeter location?	<input checked="" type="radio"/> Yes <input type="radio"/> No <input type="radio"/> N/A	<input type="radio"/> Yes <input checked="" type="radio"/> No	SWPPP signage clearly posted with the correct information and properly displayed at an obvious perimeter location.
2	Are steep slope areas not actively being worked properly stabilized?	<input checked="" type="radio"/> Yes <input type="radio"/> No <input type="radio"/> N/A	<input type="radio"/> Yes <input checked="" type="radio"/> No	Silt fence and curb protected and stabilized areas.
3	Are disturbed areas not actively being worked properly stabilized?	<input checked="" type="radio"/> Yes <input type="radio"/> No <input type="radio"/> N/A	<input type="radio"/> Yes <input checked="" type="radio"/> No	Silt fence and curb protected and stabilized areas.
4	Are natural resource areas (e.g. streams, wetlands, mature trees, etc.) protected with barriers or similar BMPs?	<input checked="" type="radio"/> Yes <input type="radio"/> No <input type="radio"/> N/A	<input type="radio"/> Yes <input checked="" type="radio"/> No	Silt fence and curb protected and stabilized areas.
5	Are discharge points and receiving waters free of any sediment deposits?	<input checked="" type="radio"/> Yes <input type="radio"/> No <input type="radio"/> N/A	<input type="radio"/> Yes <input checked="" type="radio"/> No	
6	Is trash/litter from work areas collected and placed in covered dumpsters?	<input type="radio"/> Yes <input checked="" type="radio"/> No <input type="radio"/> N/A	<input type="radio"/> Yes <input checked="" type="radio"/> No	Debris requires removal.
7	Are washout facilities (e.g. paint, stucco, concrete) available, clearly marked and maintained?	<input type="radio"/> Yes <input checked="" type="radio"/> No <input type="radio"/> N/A	<input type="radio"/> Yes <input checked="" type="radio"/> No	Concrete wash out is full and requires cleaning and removal.
8	Are vehicle and equipment fueling, cleaning, and maintenance areas free of spills, leaks or any other deleterious material?	<input checked="" type="radio"/> Yes <input type="radio"/> No <input type="radio"/> N/A	<input type="radio"/> Yes <input checked="" type="radio"/> No	

#	INSPECTION ITEM	INSPECTOR'S OBSERVATION	ACTION REQUIRED?	NOTES
9	Are materials that are potential stormwater contaminants stored inside or in containers?	<input checked="" type="radio"/> Yes <input type="radio"/> No <input type="radio"/> N/A	<input type="radio"/> Yes <input checked="" type="radio"/> No	
10	Are offsite flows entering the construction site?	<input type="radio"/> Yes <input checked="" type="radio"/> No <input type="radio"/> N/A	<input type="radio"/> Yes <input checked="" type="radio"/> No	No offsite flows entering the construction site.
11	Is there any evidence that pollutants are leaving the site or are not properly contained on site?	<input type="radio"/> Yes <input checked="" type="radio"/> No <input type="radio"/> N/A	<input type="radio"/> Yes <input checked="" type="radio"/> No	No evidence that pollutants are leaving the site.
12	Are traffic and parking areas restricted so as to reduce soil erosion and dust?	<input checked="" type="radio"/> Yes <input type="radio"/> No <input type="radio"/> N/A	<input type="radio"/> Yes <input checked="" type="radio"/> No	
13	Are non-stormwater discharges properly controlled?	<input checked="" type="radio"/> Yes <input type="radio"/> No <input type="radio"/> N/A	<input type="radio"/> Yes <input checked="" type="radio"/> No	
14	Is the project being operated in compliance with the SWPPP and with permit conditions at this time?	<input type="radio"/> Yes <input checked="" type="radio"/> No <input type="radio"/> N/A	<input type="radio"/> Yes <input checked="" type="radio"/> No	Debris requires removal. Concrete wash out is full and requires cleaning and removal.
15	Are changes to the SWPPP necessary at this time?	<input type="radio"/> Yes <input checked="" type="radio"/> No <input type="radio"/> N/A	<input type="radio"/> Yes <input checked="" type="radio"/> No	No changes to the SWPPP necessary at this time.
16	Are dust control measures being properly implemented?	<input checked="" type="radio"/> Yes <input type="radio"/> No <input type="radio"/> N/A	<input type="radio"/> Yes <input checked="" type="radio"/> No	
17	Are the SWPPP documentation and records up to date and accurately reflect the current conditions? (e.g. Site Map, Inspection Reports, Installation Dates)	<input checked="" type="radio"/> Yes <input type="radio"/> No <input type="radio"/> N/A	<input type="radio"/> Yes <input checked="" type="radio"/> No	Book not viewed onsite.

CERTIFICATION AND SIGNATURE BY INSPECTOR

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gathered and evaluated the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

INSPECTED BY:

Ray Welton

DATE:

March 03, 2021

SIGNATURE AND AFFILIATION:



CERTIFICATION AND SIGNATURE BY PERMITTEE

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gathered and evaluated the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

PRINT NAME AND TITLE:

DATE:

SIGNATURE: